

THE UNIVERSITY OF CALGARY

**An Evaluation of a Solar Heating System and other Alternatives for Energy
Conservation in a Church Building**

by

Bhakta Shakya

A THESIS

**SUBMITTED TO THE FACULTY OF GRADUATE STUDIES
IN PARTIAL FULFILLMENT OF THE REQUIREMENTS FOR THE
DEGREE OF MASTER OF SCIENCE**

DEPARTMENT OF MECHANICAL ENGINEERING

CALGARY, ALBERTA

March 1997

© Bhakta Shakya



National Library
of Canada

Acquisitions and
Bibliographic Services

395 Wellington Street
Ottawa ON K1A 0N4
Canada

Bibliothèque nationale
du Canada

Acquisitions et
services bibliographiques

395, rue Wellington
Ottawa ON K1A 0N4
Canada

Your file Votre référence

Our file Notre référence

The author has granted a non-exclusive licence allowing the National Library of Canada to reproduce, loan, distribute or sell copies of his/her thesis by any means and in any form or format, making this thesis available to interested persons.

The author retains ownership of the copyright in his/her thesis. Neither the thesis nor substantial extracts from it may be printed or otherwise reproduced with the author's permission.

L'auteur a accordé une licence non exclusive permettant à la Bibliothèque nationale du Canada de reproduire, prêter, distribuer ou vendre des copies de sa thèse de quelque manière et sous quelque forme que ce soit pour mettre des exemplaires de cette thèse à la disposition des personnes intéressées.

L'auteur conserve la propriété du droit d'auteur qui protège sa thèse. Ni la thèse ni des extraits substantiels de celle-ci ne doivent être imprimés ou autrement reproduits sans son autorisation.

0-612-20883-4

ABSTRACT

In this study, the energy performance of a solar heated building was investigated. The solar air heater was tested for thermal efficiency. To analyze the energy use characteristics of the investigated building, DOE-2.1E simulations were conducted using locally-measured meteorological data. The base case simulation model was calibrated by comparing the calculated energy use values with the actual utility bills. Theoretical analysis of the modified solar air heater was performed to assess the potential to improve performance.

The results show that significant energy savings can be achieved by separating a central system into a few systems serving smaller groups of zones. Simulated results showed that total electricity use was reduced by about 17000 kWh/year and natural gas use by about 340 GJ/year.

The results show that the solar system contributes only 50 GJ/year. The existing solar collectors work with an efficiency of less than 17 percent. By changing parameters such as the depth of the air flow channel in the collectors, the flow rate of the working fluid and the shape of the solar collector, the efficiency of the solar collector could be increased to about 38 percent.

ACKNOWLEDGMENTS

I would like to express my sincere thanks to, and respect for, my supervisor Dr. James A. Love for his advice and guidance in this research work and in the preparation of this thesis. A special thanks goes to Prof. Tang G. Lee for providing required materials for and useful advice with respect to this research work. I am also thankful to the staff of The Computer Applications Lab of the Faculty of Environmental Design for their help in overcoming obstacle after obstacle. I would also like to thank my wife Timila for her patience and encouragement throughout the research.

I am very thankful to NEEP/CIDA for providing a scholarship.

TABLE OF CONTENTS

	Page
APPROVAL PAGE	ii
ABSTRACT	iii
ACKNOWLEDGMENTS	iv
TABLE OF CONTENTS	v
LIST OF TABLES	x
LIST OF FIGURES	xi
NOMENCLATURE	xiii
CHAPTER 1: INTRODUCTION	1
1.1 Overview	1
1.2 Solar air heating system	3
1.3 Objectives and methodology	4
CHAPTER 2: LITERATURE REVIEW	7
2.1 Overview	7
2.2 Major building energy consumption components	7
2.2.1 Building envelope	7
2.2.2 Ventilation	8
2.2.3 Lighting	9
2.2.4 Infiltration	9
2.2.5 HVAC System and equipment	10
2.3 Technical and economic reviews of solar heating system	11
2.3.1 Steady-state model of solar air heater	11

2.3.2	Performance of solar collector arrays	12
2.3.3	Major factors affecting solar air heater performance	12
2.3.4	Effect of air leakage from solar collectors	13
2.3.5	Optimum tilt angle of flat-plate collector	13
2.3.6	Performance deterioration due to ambient conditions	14
2.3.7	Economic feasibility survey of solar heating systems	14
2.4	Literature review on the DOE-2 simulation program	15
2.4.1	Comparison of DOE-2 with other simplified procedures	15
2.4.2	DOE-2 verification	16
2.4.3	Input sensitivity of DOE-2	17
 CHAPTER 3: FEATURES OF THE BUILDING AND SIMULATION MODEL		
		19
3.1	Overview	19
3.2	Solar heating system	19
3.2.1	Design and operation of solar system	19
3.2.2	Curtain wall solar collector	21
3.2.3	Solar panel materials	22
3.3	Building envelope characteristics	23
3.4	space conditions	23
3.4.1	Outside air supply	24
3.4.2	Lighting and lighting density	25
3.4.3	Infiltration quantity	25
3.4.4	Occupancy schedules	25
3.4.5	Other space conditions	28
3.5	Building HAVC system and equipment	28
3.5.1	AHU units and exhaust fans	28
3.5.2	Space heating boiler	28

3.5.3	Domestic water heater	29
3.6	Thermal zoning of the building	29
3.6.1	overview	29
3.6.2	Thermal zoning	30
3.7	Calgary weather file for 1995	30
CHAPTER 4:	SOLAR SYSTEM PERFORMANCE	35
4.1	Overview	35
4.2	Solar collector testing procedure	35
4.3	Determination of collector performance metrics	37
4.3.1	Efficiency	37
4.3.2	Calculation of values needed to determine efficiencies	39
4.3.2.1	Solar time	39
4.3.2.2	Calculation of mass flow rate	40
4.3.2.2.1	Calculation of fluid density	40
4.3.2.2.2	Calculation of average velocity	41
4.4	Measurements to determine collector characteristics	41
4.4.1	Measuring instruments	42
4.4.1.1	Temperature measuring instruments	42
4.4.1.2	Velocity measuring instrument	42
4.5	Assumption for analysis	43
4.6	Solar system test results	43
4.7	Calculation of monthly useful solar energy	48
4.7.1	Monthly radiation on the tilted surface	49
4.7.1.1	Monthly average daily extraterrestrial radiation	49
4.7.1.2	Monthly average daily radiation on the horizontal surface	49
4.7.1.3	Monthly average clearness index	50
4.7.1.4	Calculation of sunset hour angles	50

4.7.1.5 Diffused component	50
4.7.1.6 Average radiation on the tilted surface	51
4.7.1.7 Value \bar{R}	51
4.7.1.8 Value \bar{R}_b	51
4.7.2 Useful solar energy calculation	53
4.7.2.1 Calculation of R_n	53
4.7.2.2 Critical radiation level	53
4.7.2.3 Value \bar{X}_c	54
4.7.2.4 Calculation of utilizability coefficient $\bar{\phi}$	54
4.7.2.5 Useful heat delivery	54
 CHAPTER 5: COMPUTER SIMULATION MODEL OF THE CHURCH	 57
5.1 The DOE-2 simulation program	57
5.1.1 DOE-2 subprograms	58
5.2 Data collection	59
5.3 Calibration of the DOE-2 model	60
5.4 Important assumptions to run DOE-2	63
5.5 Summary of building parameters	63
5.6 Data analysis and results	64
5.6.1 Building peak load components	64
5.6.2 Building energy performance summary	66
5.6.3 Comparison of monthly simulation results with utility data	67
 CHAPTER 6: ENERGY SAVING OPTIONS	 71
6.1 Elimination parametrics	71
6.2 Retrofit options	73
6.2.1 Increase in wall insulation	73
6.2.2 Retrofit of heating systems	75

6.3 Retrofit of the solar system parameters	79
6.3.1 Factors governing performance	79
6.3.2 Calculation of parameters needed to determine efficiencies	81
6.3.2.1 Top heat loss of the flat plate solar collector	81
6.3.2.2 Radiation heat transfer coefficient in rectangular duct of solar collector	82
6.3.2.3 Reynolds number	83
6.3.2.4 Collector efficiency factor	83
6.3.2.5 Collector flow factor	84
6.3.2.6 Heat removal factor	84
6.3.2.7 Useful energy gain	84
6.3.2.8 Mean plate and duct temperature	85
6.3.3 Efficiency	85
6.3.3.1 Summary of the efficiency calculation	85
 CHAPTER 7: CONCLUSIONS AND RECOMMENDATIONS	88
7.1 Summary of work completed	88
7.2 Summary of results and conclusions	89
7.2.1 Results and conclusions on the existing solar air heating system	89
7.2.2 Results and conclusions of retrofit options	90
7.3 General conclusions	91
7.4 Recommendation for future work	91
 References	93
Appendixes	96

LIST OF TABLES

Table	Title	Page
3.1	Glazing properties	23
3.2	Calgary weather summary for 1995	31
4.1a	Solar analysis data	45
4.1b	Solar analysis data	46
4.2	Average daily extraterrestrial radiation	49
4.3	Daily radiation on horizontal surface	49
4.4	Clearness index	50
4.5	Monthly value of n, δ, ω_s	50
4.6	Irradiation on the tilted surface of the solar collector based on 1995 weather data for Calgary	52
4.7	Calculation parameters for solar air heater analysis	55
4.8	Useful solar heat gain for 1995	56
5.1	Summary of building parameters	63
5.2	Simulated building peak heating load components	65
5.3	Simulated building energy summary for 1995	66
6.1	Simulated building annual energy use summary after thermal insulation retrofit	74
6.2	Parameters to determine efficiency of the solar collector (based on incident radiation of 600 W/m^2)	86
6.3	Efficiency of the solar collectors (existing and retrofit)	86

LIST OF FIGURES

Figure	Title	Page
1.1	Exterior view of the south-facing facade	3
3.1	Schematic diagram of active charge-passive discharge solar heating system	20
3.2	Curtain wall solar collectors	22
3.3	Occupancy schedule for different facilities	26
3.4	Occupancy schedule for C/L sanctuary	27
3.5	Basement floor plan	32
3.6	Main floor plan	33
3.7	Mezzanine floor plan	34
4.1	Solar collector temperature measuring points	36
4.2	Characteristic efficiency curves for the air heating flat-plate collector plotted as function of T_{av}	47
4.3	Characteristic efficiency curves for the air heating flat-plate collector plotted as function of T_i	48
5.1	DOE-2 program flow chart	58
5.2	Flow chart of data analysis	62
5.3	Simulated and metered natural gas consumption for 1995	68
5.4	Simulated and metered electrical energy consumption for 1995	69

6.1	Simulated annual electricity consumption for the building, elimination parametrics	72
6.2	Simulated annual natural gas consumption for the building, elimination parametrics	74
6.3	Simulated annual electricity consumption: base case envelope and envelope with double insulation	74
6.4	Simulated annual natural gas consumption: base case envelope and envelope with double insulation	75
6.5	Retrofit HVAC system model	76
6.6	Simulated annual electricity consumption for base case and system retrofit building	77
6.7	Simulated annual natural gas consumption for base case and system retrofit building	78
6.8	Assumed collector dimension	81

NOMENCLATURE

ACRONYMS:

OPEC	Organization of Petroleum Exporting Countries
HVAC	Heating, Ventilation, and Air Conditioning
ASHRAE	American Society of Heating, Refrigerating, and Air Conditioning Engineers
DOE	The U.S. Department of Energy
DOE-2.1E	Building Energy Simulation Program Sponsored by DOE
WYEC	Weather Year for Energy Calculations

SYMBOLS:

C2000	Program for Advanced Commercial Buildings, Natural Resources Canada
Q_u	Useful heat gain (W)
C_p	Specific heat of the fluid (J/kg°C)
T_o, T_i	Outlet and inlet temperature of the collector (°C)
T_a	Ambient temperature (°C)
A_c	Aperture collector area (m²)
F_R	Heat removal factor
G_T	Instantaneous solar radiation (W/m²)
($\tau\alpha$)	Transmittance-absorptance product
U_L	Collector overall energy loss coefficient (W/m²°C)

\dot{m}	Mass flow rate (kg/s)
η_i	Instantaneous efficiency
L_{st}	Standard meridian for the local time zone
L_{loc}	Longitude of the location
E	Equation of time
ρ	Density of air (kg/m ³)
V	Average velocity (m/s)
P	Absolute pressure (Pa)
R	Gas constant for the air (J/kgK)
ν	Kinematics viscosity (m ² /s)
\bar{H}_T	Monthly average daily radiation per unit area on the tilt surface (MJ/m ²)
\bar{H}_o	Extraterrestrial radiation (MJ/m ²)
\bar{H}	Monthly average daily radiation on the horizontal surface (MJ/m ²)
\bar{K}_T	Monthly average clearness index
ϕ	Latitude of the location
δ	Solar declination
ω_s	Sunset hour angle
n	Mean day of the month, number of glass covers
\bar{H}_d	Diffused component of solar irradiation (W/m ²)
ρ_g	Diffuse reflectance of ground
β	Sloped surface angle (degree)

\bar{R}	The average ratio of the total radiation on a tilted plane to that on the horizontal
\bar{R}_b	The ratio of the average daily beam radiation on the tilted surface to that on a horizontal surface for the month
\bar{H}_{bT}	Average daily beam radiation on the tilted surface (J/m^2)
R_n	The ratio of radiation on the tilted surface to that on a horizontal surface at noon for an average day of the month
$r_{T,n}$	The ratio of radiation at noon to the daily total radiation
$r_{d,n}$	The ratio of diffuse radiation at noon to the daily diffuse radiation
I_{TC}	Critical radiation level (W/m^2)
T_{im}	Average inlet temperature for the month ($^{\circ}\text{C}$)
T_{amb}	Average ambient temperature for the month ($^{\circ}\text{C}$)
\bar{X}_c	The ratio of the critical radiation to the radiation at noon for the average day during the month in which the total radiation for the day is the same as the average for the month
$\bar{\phi}$	Utilizability coefficient
N	Number of days in the month
λ	Air thermal conductivity ($\text{W/m } ^{\circ}\text{C}$)
μ	Air dynamic viscosity (Pa s)
h_c	Convective heat transfer coefficient ($\text{W/m}^2 ^{\circ}\text{C}$)
L	Length of collector (m)
b	Thickness of air flow channel (m)

D_e	Equivalent diameter (m)
ε_p	Plate emittance
ε_g	Glass emittance
T_{mp}	Mean plate temperature (K)
h_w	Wind heat transfer coefficient ($W/m^2\ ^\circ C$)
σ	Stefan-Boltzmann constant
T	Main fluid temperature
Re	Reynolds number
A_f	Fluid flowing area (m^2)
U_t	Top heat loss coefficient ($W/m^2\ ^\circ C$)
F'	Collector efficiency factor
h_r	Radiative heat loss coefficient ($W/m^2\ ^\circ C$)
F''	Collector flow factor
F_R	Heat removal factor
T_{mp}	Theoretical mean plate temperature ($^\circ C$)
T_{mf}	Theoretical mean fluid temperature ($^\circ C$)

CHAPTER 1

INTRODUCTION

1.1 Overview

A dramatic increase in the price of energy as a result of the 1973 oil embargo and later OPEC pricing strategy together with rapidly increasing energy demand has forced people to think about energy conservation. As a result of this situation, energy conservation in the sense of energy efficiency and the use of renewable energy is vital.

It has been estimated that roughly one-third of the national annual consumption of primary energy is used for building services in the US and Canada [1]. Energy consumption and the efficiency of energy use in buildings depend on design and the conservation strategies that have been taken to save energy.

Components such as building materials, orientation, shape, percentage of glazing area, HVAC system, ventilation, and lighting density are highly dependent on the design of the building. These components play an important role in building energy use. In general, three basic systems determine the efficiency of energy use in buildings [2]:

- energized systems, such as those required for heating, cooling, lighting, ventilation, business equipment operation, etc.**
- nonenergized systems, such as walls, roofs, floors, windows.**

Solar heating of buildings with air as a working fluid has been used for a long time in the USA and other countries. The feasibility of solar heating is a function of several things such as initial cost, installation cost, heating fuel cost, and geographic and atmospheric conditions. Because of high installation costs, payback periods can be long, especially in places where energy prices are low. Solar heating systems might be feasible in northern climates like Calgary's if the systems (i.e., structure plus solar system) are integrated architecturally [5]. In addition, solar systems may help to improve environmental quality by reducing the use of fossil fuels.

1.2 Solar air heating system

In this study, a church with a curtain wall acting as an active flat plate solar collector and a partition wall acting as an energy storage subsystem was selected for performance evaluation. Figure 1.1 shows an exterior view of the building with south-facing collectors for active collection of solar energy.



Figure 1.1 Exterior view of the south-facing facade

- **human systems, such as maintenance, operation, and energy management.**

Each of these systems can be modified for significant savings of energy. However, modifications must be analyzed in terms of comfort of occupants, cost-effectiveness and pollution control.

Before designing energy strategies for commercial buildings, a clear picture of the most significant components of energy utilization should be developed based on annual energy use patterns. Methods of conservation should then be applied to get desired energy savings. For cold climate regions, heating is the largest annual energy consumption component followed by ventilation, lighting, and cooling [3]. In terms of annual energy expenditure, electricity is the major energy cost for buildings in cities like Calgary, because of the relatively low cost of natural gas.

One of the ways to improve the energy performance of buildings in cold climates is to employ solar heating systems that could reduce fossil fuel requirements for heating. Generally, the earth receives solar energy at a rate of 5.6×10^{24} J/year which is equivalent to about 30,000 times the energy used at the present time [4]. Utilization of this huge amount of renewable energy requires knowledge of the nature of solar insolation, the factors that influence its intensity and systems that utilize such energy.

In most cases, whether air or water is the working fluid, simple flat plate collectors with selective and nonselective absorber plates are used, because of their relatively low cost of construction compared with other types of collectors such as concentrating systems.

This solar heating system consists primarily of solar collector panels, a masonry wall for thermal storage, a heat exchanger for water preheating, a circulation fan, ducting, and a control system to operate the system properly. All mechanical and structural components are connected via a duct network. A detailed description of the building is given in Chapter 3.

Solar radiation on the collector surface passes to the absorber surface; consequently the absorber surface becomes heated. The absorber's surface temperature depends on the radiation level on the surface and the optical and thermal properties of the collectors. As a result of heat transfer between the absorber plate and circulated air, air leaving the collector part of the system should be hotter than at the inlet. After pre-heating domestic hot water (DHW) via the air-to-water heat exchanger, the air gives up the remaining heat gained to the thermal storage wall.

The main disadvantage of this type of system is that significant temperature swings are needed in the building to provide maximum exploitation of the solar heating. Higher temperature swings in the building could affect occupant comfort. However, the system is a good alternative to systems with active discharge storage [6].

1.3 Objective and methodology

This research had the following objectives:

- to evaluate the performance of the building-integrated solar air heating system in terms of energy gain.**
- to evaluate the solar heating option relative to other energy conservation strategies.**

The major steps for this study were as follows:

- **obtain utility meter data (i.e., natural gas and electricity consumption) for the building for one year (1995).**
- **prepare an hourly 1995 weather file for Calgary; this was required for energy use simulation and for calculation of solar heat collection.**
- **determine the amount of annual heat collection from the solar air heater.**
- **prepare a DOE-2 simulation model of the investigated building and calibrate it with the metered and weather data for 1995.**
- **evaluate possible retrofits for the investigated building by computer simulation.**
- **determine performance of retrofitting the solar collector.**

Beyond this chapter, Chapter 2 contains a literature review of basic factors that govern building energy use and solar air heater performance, and on the performance and validation of the DOE-2 simulation program. Chapter 3 presents features of the building, envelope constructions, operating conditions, and the HVAC/DHW equipment, and summary of Calgary weather files for 1995. Chapter 4 presents efficiency calculations for the solar air heater and the solar system's annual heat accumulation. Chapter 5 presents the calibration of the simulation model based on the building energy use data and concludes with DOE-2 simulation results. Chapter 6 contains results of computer simulation of possible retrofits of the building in terms of energy conservation and theoretical analysis of the solar system in terms of changing parameters such as air gap and flow rate from the existing design. Chapter 7

concludes the research with conclusions and some recommendations for future work.

CHAPTER 2

LITERATURE REVIEW

2.1 Overview

Many papers have been written on energy conservation in office, school, and hotel buildings, but it is very hard to find out about energy conservation in church buildings. Because of their function, religious buildings differ from the others in terms of energy requirements. Factors such as occupancy schedules, daily activity and facilities provided in the church could lead to differences from other buildings. Often, architectural design and facility use change the energy use characteristics of buildings and consequently, conservation methods.

In this literature review, papers dealing with major building components that affect building energy consumption are discussed first. Second, papers related to performance factors and economic feasibility of solar heating systems are considered. Third, research that has been done on the performance of DOE-2 and its sensitivity to user decisions are discussed.

2.2 Major building energy consumption components

There are many components that affect energy consumption in buildings. These are briefly discussed below:

2.2.1 Building envelope

An architect's ability to properly develop the functional and esthetic features of a building is very important in controlling heating and cooling requirements, as well as corresponding initial and operating costs. Geographic location,

variation of outside temperature and wind and solar intensities are influential factors in building envelope design. The ultimate choice of the building configuration should be determined based on both design and energy issues [3].

Heat loss from the envelope depends on many factors, other than climate conditions, such as structure, window to wall ratio (WWR), U-value (i.e., wall, roof, floor, and window), geometrical shape, orientation, and others. Out of these characteristics, WWR is one of the most significant factors affecting energy demand. Hence, it should be determined through economic analysis for the specified geographic location [7,8].

2.2.2 Ventilation

The ventilation rate is one of the basic factors that affects annual energy use, equipment sizing and first cost of HVAC systems. For offices, the old ASHRAE Standard 62-81 recommended 2.3 l/s/person without smokers and 9.4 l/s/person with smokers [9]. ASHRAE Standard 62-89 does not distinguish the presence of smoking and simply recommends a minimum of 9.4 l/s/person [10]. This new standard for outside air rate, based on indoor air quality, remains a subject of debate. The outdoor ventilation air requirements specified by ASHRAE exceed rate to meet oxygen replacement requirements and control carbon dioxide concentrations which, for normal activities, are about 0.6 and 1.8 l/s/person respectively [11].

According to Eto and Meyer [12], the changes in the ventilation rate from the former standard would increase chiller and boiler size up to 20 and 10 percent respectively. The largest increases in boiler capacity occur in colder climates and the smallest in milder ones. The largest increases in chiller capacity are found in climates with the greatest cooling requirement. HVAC first costs

increase by less than US \$ 0.35/ m². Annual energy use for heating would increase by up to 8 percent and annual energy use for cooling by up to 14 percent.

One way to reduce the ventilation cost or life cycle cost of HVAC system is through heat recovery devices. Waste heat recovery devices such as run-round heat exchangers, heat pipes, and rotary air-to-air regenerative heat exchangers (heat wheels) are widely used in HVAC systems.

2.2.3 Lighting

Lighting systems are designed to create safe and pleasing visual working environments. Lighting systems use a large portion of a building's energy. Lighting may represent 23 percent or more of the total energy consumption in commercial buildings and it has an impact on the energy consumption of the HVAC system [2]. The lighting system has a greater impact on the annual cooling energy used in warm climates than in cold climates.

Efficient lighting systems not only decrease electrical energy costs but also decrease the operating cost of air-conditioning in hot climates. For example, according to Shavit and Richard [13] an individual dimmable electronic ballast system could save 64, 5, and 12 percent for the lighting, fan and chiller systems respectively.

2.2.4 Infiltration

One of the major loads in commercial buildings is infiltration of outside air through cracks around doors and windows, and when exterior doors are used. According to the C2000 program [14], this is one of the major factors that

reduces the energy efficiency of buildings. Energy losses from infiltration can be substantially reduced through improved sealing of the air flow paths.

2.2.5 HVAC Systems and equipment

HVAC systems differ according to the precise location of the heating and cooling coils in the air stream and according to the manner in which systems meet varying space loads in each zone. Energy conservation standards are particularly difficult to develop for HVAC systems. The factors that affect the energy performance of HVAC systems are difficult to describe. Some of the recent general recommendations for HVAC systems for heating dominated climates are [15]:

- the elimination of simultaneous heating and cooling of supply air for a single conditioned space (a major objective of efforts to improve the efficiency of HVAC systems).
- use of automatic off-hour control (time clock).
- large central systems should have options to isolate zones or small groups of zones during unoccupied periods.
- optimal insulation thickness.
- minimum leakage of air distribution system to avoid energy losses.
- use of systems with an economizer cycle.
- use of heat recovery systems.

- **use of direct digital control systems for better energy management.**
- **use of variable speed pumping systems (can save considerable pumping energy, especially in large distribution systems).**
- **use of renewable energy sources if economically justified.**

In studying the influence of these options on energy consumption, computer modeling of buildings can help greatly. In addition, simulation makes it possible to individually evaluate the impact of each parameter on energy use.

2.3 Technical and economic reviews of solar heating system

2.3.1 Steady-state model of solar air heater

Winter [16] concluded that, even though solar radiation, wind speed, ambient temperature and the building heating load vary continuously, steady-state models are adequate for estimating performance of conventional flat plate collectors if hourly meteorological data are used. In other words, transient effects can be ignored for calculation of the collector performance.

According to Duffie and Beckman [6], the following assumptions can be made to simplify calculation of a collector's heat transfer:

- **steady-state conditions.**
- **uniform flow of the fluid in the collectors**
- **no absorption of solar energy by collector covers**

- one dimensional heat flow
- temperature gradients along the collector plate may be neglected
- isotropic sky conditions
- material properties are independent of temperature

2.3.2 Performance of solar collector arrays

Duffie and Beckman [6] noted that performance of a solar collector array differs from that of an individual collector. It could drop to half the efficiency predicted for a single collector because of the following reasons:

- increases in heat and pressure losses from array connections.
- flow maldistribution among the collectors.
- large thermal capacitance or amount of heat absorbed by the body of the collectors.
- occasional mutual shading of collectors.
- air leakage from the collectors (at gaps in sealant)

2.3.3 Major factors affecting solar air heater performance

In the case of solar air heaters, flow rate and the geometric construction of the collector strongly influence the efficiency. This is expressed by the convective heat transfer coefficient (h_c). Biondi et. al. [17] reported that, assuming

factors such as inlet temperature, environment parameters and materials of construction to be constant, the performance of a collector is solely determined by two factors: the specific air flow rate or mass flow rate per unit area of solar collector and the geometry of the solar air heater. Graphs produced for different values of geometric coefficient and specific flow rate show that both these parameters have equal influence on the collector performance. More detail on this subject is given in Chapter 6.

2.3.4 Effect of air leakage from solar collectors

Because of the pressure difference between collector air streams and the atmosphere, most conventional collectors experience leakage, which significantly affects performance. Two situations may occur: significant quantities of air may leak into or out of the collectors. In the former case, air leaking into the collector must be heated from the outdoor temperature to the outlet temperature of the collector, which requires more energy than heating of the recirculation air. In the latter case, less air passes through the collector. This reduces the performance of the collector, because efficiency of the collector is highly dependent on the mass flow rate in the collector. Close and Yusoff [18] reported that air leakage should be accounted for in collector efficiency measurements even if a constant leakage rate must be assumed, otherwise the leaked air will appear as an extra load on the collector.

2.3.5 Optimum tilt angle of flat-plate collector

Optimum tilt angle of a flat-plate collector is one of the factors that affects solar system performance. There is a range of tilt angles that gives near-maximum solar heat gain during a whole year of application. The optimum tilt angle for a collector is a function of the latitude and the seasonal application

(i.e., for space heating or water heating). For year round application, different investigators propose varying tilt angles to obtain maximum collector performance. Mustafa's [19] study showed that changing the tilt angle by about $\pm 10^\circ$ from its optimum angle reduces the amount of the monthly absorbed radiation by less than 3 percents.

Based on his analysis, the optimum tilt angle for Calgary, with a latitude of 51° , approximate clearness index (\bar{K}_T) of 0.5 and ground reflectance of 0.7 for January, February, November, and December lies between $70^\circ - 80^\circ$ for space heating.

2.3.6 Performance deterioration due to ambient conditions

Grag [20] reported that ambient dust could decrease performance of solar collectors. Energy absorbed by the collector is not only a function of the optical and thermal properties of the collector, but also a function of many factors such as ambient dirt concentration, inclination angle of the collector, exposure time without rain, and type of cover plate. He mentioned that the transmittance could be reduced by 1 percent in a moderately clean atmosphere.

2.3.7 Economic feasibility survey of solar heating systems

A survey conducted by Roger et. al. [21] in 1977-1978 addressed the economic feasibility of solar water and space heating for single-family residences and multi-family apartment buildings in four US cities: Boston, Washington, Grand Junction, and Los Angeles. In this study, economic criteria such as payback period, years to recovery of down payment, and years to net positive cash flow were used. The cost competitiveness of solar

systems compared with heating systems based on electricity, fuel oil, and natural gas were analyzed, taking into account federal incentives for solar systems. The authors found that combined solar water and space heating is only marginally feasible for single-family residences. Tax incentives made solar systems competitive with electricity in all four cities, but for multi-family apartments the relationships were unclear. In addition, combined solar water and space heating systems are not economically feasible in any of the four locations when compared to natural gas even with the federal investment tax credit.

2.4 Literature review on the DOE-2 simulation program

The building energy simulation program DOE-2 was chosen to analyze the building that was investigated in the study reported here. It computes hourly heating and cooling loads. It has the capacity to simulate dynamic heating and cooling loads, amount of air supply, equipment sizing, and economic evaluation for the selected time period. Generally, it is used as a preliminary design tool to calculate energy consumption for different options in a new building. Recently, it has also been used as a simulation tool to analyze the economic impact of different retrofit options. This is one of the few computer programs recommended by ASHRAE for building energy analysis [15]. This section addresses publications on the performance, validation, and input sensitivity of DOE-2.

2.4.1 Comparison of DOE-2 with other simplified procedures

Energy calculations were carried out for a variety of house types such as ranch, split-level, two-story detached, and townhouse in ten different US locations using DOE-2. From simulation results, Kusuda [22] reported that,

DOE-2 could be a good alternative to the energy analysis procedures such as the degree-day and the ASHRAE TC 4.7 bin method for building energy calculation.

For single-story residences, all the heating loads calculated using variable-base degree-day fell within 10 percent of those computed by DOE-2, while 50 percent fell within 5 percent. For two-story residences, all heating loads fell within 20 percent and cooling loads fell within 15 percent except for one of the locations studied.

Almost all points obtained with TC 4.7 fell well within 15 percent of the DOE-2 results. Both comparisons show that the DOE-2 simulation program could be used as an alternative to the simple methods .

2.4.2 DOE-2 verification

The DOE-2 Verification Project conducted by Diamond and Hunn [23] used DOE-2 to model seven existing commercial buildings. These buildings included a restaurant, a single-floor office building, a retail store, a hospital, a multifloor office building, a school, and a solar-heated and-cooled building. Each building was simulated by contractors, except the solar building and the school, which were done by Lawrence Berkeley Laboratory (LBL). Simulated results were compared to utility data for monthly and annual periods. Simulation results showed that DOE-2 is highly sensitive to the data entered by the user. Higher deviations in monthly results relative to annual results may be due to actual building parameters differing from standard schedules for occupants, lights, equipment, DHW and long term weather data. Annual results for these buildings show that the standard deviation between simulated and metered values for gas/fuel oil, electricity and total energy

consumption was 11, 9, and 8 percent respectively. The absolute difference between predicted and measured monthly data ranged from 14 to 45 percent for gas/fuel oil, 13 to 37 percent for electricity, and 15 to 33 percent for total energy use. In spite of large deviations for a few individual months, statistical analysis of all months for these buildings shows "composite" (all buildings combined) standard deviations of 26, 19, and 17 percent for gas/fuel oil, electricity, and total energy consumption respectively.

2.4.3 Input sensitivity of DOE-2

To determine the effects of user judgments regarding interpretation of input data on the simulation results, Diamond et. al. [24] assigned six experienced DOE-2 users to make DOE-2 models of four commercial buildings. These buildings included the single-floor office building, multifloor office building, retail store, and restaurant. Initially, less detailed input data was given for the assigned buildings. This was supplemented in stages so that three levels of increasingly refined input data were used. These were: (1) uncontrolled input (2) refined input and (3) input constrained by the Standard Evaluation Technique (SET) defined for the Building Energy Performance Standards (BEPS) proposed by the U.S. Department of Energy (DOE). For uncontrolled input, the buildings and their operation were described as they would be to a consultant conducting an energy audit. Assumptions concerning missing information and ambiguities were left to the contractors. For the refined input level, missing data were supplied, gross ambiguities in data were eliminated, and analyst's questions regarding the buildings were answered. For the Standard Evaluation Technique, fixed parameters were used such as: weather data, standard building operating conditions, and selected fixed-data input values.

The results of the experiment were presented in terms of monthly standard deviation among multiple users for the three sets of input specification. The reduction of scatter in the monthly total energy prediction was about 40 percent when information supplied to analysts improved from uncontrolled to refined. Similarly, scattering was further reduced about 30 percent when information improved from the refined to SET input. In addition, results also show greater variations in fuel energy than in electrical energy consumption. The study indicated that scatter in results can be reduced significantly by having an independent observer check the input for errors and by eliminating gross ambiguities in the input.

CHAPTER 3

FEATURES OF THE BUILDING AND SIMULATION MODEL

3.1 Overview

The Sandstone Valley Ecumenical Centre was built in 1987. It is located at 1100 Berkshire Boulevard, N.W., Calgary, Alberta. The building lies at 51° north latitude, 114° west longitude, and 1,100 metres elevation. The three-story structure, including basement, has a floor area of approximately 3,300 m². A plan of each floor is given at the end of this chapter. The building is not shaded by nearby structures or trees. The building consists of two sanctuaries, a chapel, a fireside lounge, a lobby, a gymnasium/hall with commercial kitchen facilities, a recreation centre, a nursery, and administrative offices. To reduce operating costs and for social reasons, the building facilities are shared by Catholic and Lutheran congregations.

3.2 Solar heating system

3.2.1 Design and operation of solar system

The architecturally integrated active charge-passive discharge solar system, as shown in figure 3.1, consists primarily of solar collector panels, a thermal mass masonry wall, a heat exchanger for water preheating, a circulation fan, a control system, and ducting. All mechanical and structural components are connected in a closed loop.

The absorber's surface temperature depends on the radiation incident on the surface and on the optical and thermal properties of the collectors. As a result

of heat transfer between the absorber plates and circulated air, air leaves the collector area with a higher temperature than at the inlet. Useful heat gain from the system is possible only when the incident radiation is sufficient to exceed losses in the collector.




Figure 3.1 Schematic diagram of active charge-passive discharge solar heating system

Gross collectors area :

$$A = 28 \text{ m}^2$$

$$B = 18 \text{ m}^2$$

$$C = D = 14 \text{ m}^2$$

$$E = F = 13.5 \text{ m}^2$$

Heated air from the absorbers' surfaces is circulated by a fan via a duct network. The fan delivers 700 l/s at static pressure of 0.5 kPa (2 in H₂O). The calculated air flow per unit area of solar panel is given in Chapter four. After pre-heating domestic hot water via the air-to-water heat exchanger, the air gives up the remaining heat accumulated in the collectors in the thermal storage wall.

The thermal storage wall stands between the gymnasium and recreation centre. This thermal storage structural wall also functions as a primary structural support, a fire separator and a sound attenuator between the gymnasium and adjacent spaces. The area of the thermal storage is twice that of the solar collector, the ratio the designers determined to be most efficient [5]. It has an area of approximately 200 m².

The system was designed to deliver heat when the collectors reach 35 °C and to shut off 3 °C below this set point. Overheating protection is accomplished with motorized inlet and exhaust dampers. If the temperature of the solar heated air rises to 60 °C, these dampers open to the atmosphere such that the overheated air may be purged. Two automatic dampers located above and below the solar panels act to prevent excessive rise in temperature of the solar panels in case of power failure.

3.2.2 Curtain wall solar collector

A distinguishing feature of the building is the south-facing glass-clad wall, which is designed to act as the collector of the solar system. Wall construction is shown in figure 3.2.




Fig. 3.2 Curtain wall solar collectors

The collectors vary in size and shape as dictated by the shape of the facade. Figure 3.1 shows collector shapes.

3.2.3 Solar panel materials

The solar collectors are glazed with a single pane of clear 6 mm tempered float glass and the absorber plates are 20 GA galvanized sheet steel painted with flat black high temperature paint.

3.3 Building envelope characteristics

Major exterior wall and roof constructions, excluding interior finishes, of the building are given in Appendix A1.

Exterior windows are fixed and clear double-glazed units except the window just below solar collector A (see figure. 3.1). This is triple-glazed with an approximate area of 7 m². Glazing U-values and shading coefficients were taken from the DOE-2 window library [25]. Values are shown in the Table 3.1 with DOE-2 glass-type-codes.

Exterior	Glass-type-code	Heat transfer coeff.	Shading coeff.
Triple-glazed	3002	1.8 W/m ² C	0.8
Double-glazed	2004	2.7 W/m ² C	0.8
Single-glazed	1001	6.2 W/m ² C	0.9

Table 3.1 Glazing properties

Near the middle of the building's longest axis, a skylight admits natural light. It has area of approximately 14 m². A heat transfer coefficient or U-value of 5.9 W/m²K is assumed for this construction.

3.4 Space conditions

As mentioned earlier, features that significantly influence energy consumption are highly important for energy use simulation. These values were collected at the site, from architectural drawings, or based on typical conditions. A brief discussion of these parameters is presented below.

3.4.1 Outside air supply

Ventilation is very important in maintaining adequate indoor air quality. Ventilation is a process that introduces the outside air or fresh air into the occupied spaces. Its quantity has substantial effect on building energy consumption.

In this study, the ventilation rate was assumed to follow ASHRAE standard 62-81 because the building was constructed before ASHRAE standard 62-1989. There are three air handling units.

AHU-1: Catholic and Lutheran sanctuaries, lobby, mezzanine class rooms, main vestibule, and mezzanine core zone (4.7 L/s/person or 10 cfm/person).

AHU-2: basement and main floor service zone, chapel, and play room (7.1 L/s/person or 15 cfm/person).

AHU-3: gymnasium/hall (7.1 L/s/person or 15 cfm/person).

To minimize ventilation heating load for AHU-3 a run-around heat exchanger is used to recover some heat from the exhaust air.

The quantity of outdoor air is controlled based on the outdoor air temperature by a ventilation position selector. The higher the outdoor temperature, the more outdoor air is introduced in to the spaces. This control would be set at its minimum position during winter.

3.4.2 Lighting and lighting density

Lighting systems are designed to meet architectural and visual requirements of the spaces. In most of the spaces, a combination of fluorescent and incandescent lighting was found. The simulation program allows only one type of lighting system for a space. Thus, the dominant light fixture in terms of lighting power was chosen for simulation.

In most of the spaces, a lighting power density of about 15 W/m^2 was found except in one office room (recently used as a morning class room) which has 5.5 W/m^2 . These data show that the lighting system seems efficient in terms of power density.

3.4.3 Infiltration quantity

For this building, as per ASHRAE [26] recommendations, infiltration was taken to be that of a tight building envelope ($200 \text{ cm}^3/\text{s m}^2$). According to Parker and McQuiston [27], the amount of infiltration for vestibules is $8100 \text{ cm}^3/\text{s m}^2$; this includes infiltration for walls, door cracks, and infiltration due to traffic.

3.4.4 Occupancy schedules

Schedules were based on several visits and information available from the building operators and the administration. However, they might not be accurate for all seasons or every year. Because of the range of facilities provided in this building, it was necessary to make different schedules for different parts of the building. The occupancy fraction was assumed to be 100 percent when occupied, but in reality it might be different. Occupancy schedules for dominant spaces are demonstrated in figures 3.3 to 3.4.




Figure 3.3 Occupancy schedules for different facilities




Figure 3.4 Occupancy schedules for Catholic and Lutheran sanctuaries

3.4.5 Other space conditions

Heat gain from people was selected for light working conditions and set to 120 W/person (420 Btu/hr/person) except for the gymnasium/hall at 375 W/person (960 Btu/hr/person) [28].

Based on monitoring of temperature in one of the sanctuaries for one week, the room temperature for winter was found to be 20 °C.

Ten percent of lighting was assumed to be in use in areas such as administration and mezzanine floor class rooms during unoccupied periods and at night time.

3.5 Building HVAC system and equipment

3.5.1 AHU units and exhaust fans

The building HVAC system is designed for winter heating. During the summer season, free cooling of the building is used. The building HVAC system consists of three constant-volume air systems with radiative (hot water) heating around the building perimeter. Four exhaust fans are provided for the washrooms (main floor), kitchen hood (gymnasium/hall), dryer (gymnasium/hall), and washrooms (mezzanine floor). The capacity and specifications of AHU units and exhaust fans are given in Appendix A2.

3.5.2 Space heating boiler

The plant equipment includes two natural gas-fired boilers rated at 316 kW each. These boilers have two firing stages. Natural gas flow rates in each

stage and corresponding efficiencies are given in Appendix A2. Gas flow rates and efficiencies were determined on site [29].

3.5.3 Domestic Water Heater (DWH)

There are two DWH heaters rated at 95 kW each. Both these DWHs are the single stage firing type. Measured gas flow rates and efficiencies [29] are given in Appendix A2. Each DWH has a heating capacity of 1,270 l/hr.

Mansour [29] reported that hot water consumption is negligible relative to the design value. This is because facilities such as gymnasium showers and the kitchen were not used as planned. This was verified during several visits to the site.

3.6 Thermal zoning of the building

3.6.1 Overview

It is well known that the perimeter area adjacent to the exterior wall and windows is most affected by temperature differences between the outside and the inside of the envelope. Factors such as heat loss or gain through the envelope, infiltration, and solar radiation will change thermal conditions in these perimeter areas. On the other hand, thermal conditions of the core zone of any building are determined by internal heat gains. For simultaneous control of both perimeter and core zone thermal conditions during the heating season, cooling as well as heating may be required.

Because the major internal heat gain (sanctuaries) is for short periods and the building is designed only for heating, thermal zoning of the building was done according to the function of the space ignoring the fact mentioned above.

3.6.2 Thermal zoning

Zones in each floor and their associate places are as follows:

Basement: 5 zones

1- gymnasium/ hall, 2-washroom with changing rooms, cafeteria, and storage, 3- staircase, 4- recreation centre and store, 5- basement corridor.

Main floor: 6 zones

1- nursery, 2- administration, 3- chapel, 4- catholic sanctuary, 5- lutheran sanctuary, 6- lobby.

Mezzanine: 7 zones

1- office, 2- corridor, 3- core, and W/R, 4- lutheran/catholic mezzanine room, 5- mechanical (uncondition), and 7- play room.

Altogether there are three vestibules, one in the basement and two on the main floor. During several visits to the building, it was noticed that only one vestibule is commonly used. In the simulation mode, only one vestibule is used for the building energy analysis. The rest of the vestibules are treated as envelope for infiltration. In Figures 3.5 to 3.7, at the end of the chapter, floor plans show the zoning of the building.

3.7 Calgary weather file for 1995

In terms of climatic condition, Calgary's high altitude and dry and fairly clean atmosphere with 2,200 hours/year bright sunshine indicates a good potential for solar energy [29]. To increase accuracy in simulation and calculation of solar gain from the solar air heater, an hourly weather file was prepared for 1995. Data recorded at The University of Calgary, Alberta, were used. By re-formatting the recorded data, a WYEC (Weather Year for Energy

Calculations) format weather file was prepared. This WYEC format weather file consists of 8760 records, one for each hour of the year. Each record has 116 characters. Details of the WYEC format are available from the Atmospheric Environment Service of Environment Canada in Downsview, Ontario.

The DOE-2 simulation program needs an hourly weather file to simulate building energy use. Table 3.5 presents a brief monthly summary of the 1995 weather file. However, for more representative energy consumption forecasting or building energy analysis, it is better to have a file representative of long-term weather patterns.

	Monthly average daily radiation on horizontal surface	Monthly Average daily Outside temperature	Heating Degree Days
Month	MJ/m ²	T _a °C	°C
Jan.	4.9	-6.0	774
Feb.	5.6	-5.0	671
Mar.	13.4	-2.2	653
Apr.	15.9	3.1	466
May	20.7	9.5	292
Jun.	21.0	14.1	148
Jul.	19.4	15.4	107
Aug.	19.4	13.5	155
Sep.	15.3	11.8	209
Oct.	9.0	5.3	432
Nov.	4.6	-4.2	665
Dec.	3.7	-9.8	861
		Total	5433

Table 3.5 Calgary weather summary for 1995




Figure 3.5 Basement floor plan




Figure 3.6 Main floor plan




Figure 3.7 Mezzanine floor plan

CHAPTER 4

SOLAR SYSTEM PERFORMANCE

4.1 Overview

This chapter details the testing procedure and the results for the existing solar heating system. It describes how the efficiency and thermal performance factors were measured and calculated. Secondly, the useful monthly solar energy received from the solar heating system for 1995 is calculated using the daily utilizability method.

Generally, thermal performance testing of solar collectors is conducted to determine three parameters: 1) the instantaneous efficiency of the collector, 2) the effects of angle of incidence of incident radiation, and 3) the heat capacity of the collector in terms of time constant. In this study, the collector was only tested for instantaneous efficiency because the other two factors were not relevant to this study.

4.2 Solar collector testing procedure

The thermal performance of any solar system varies depending on parameters such as operating temperature, flow rates, solar insolation, orientation, tilt, time of day, wind condition, outdoor temperature, clearness index, and geometry of the solar collector. Despite the transient effect of all these variables on the thermal performance, steady-state conditions are adequate for estimating solar collector performance [16]. The testing procedure used in this project allows the determination of the fundamental characteristics of a collector. The temperature measuring points for testing of the closed-loop solar system are shown in figure 4.1.

T _____

TP _____

TP - Te _____

The tes _____

- run _____
- mea _____
- mea _____
- mea _____
- mea _____
- mea _____

These p _____

4.3 Determination of collector performance metrics

4.3.1 Efficiency

Assuming steady-state conditions, the useful gain by the solar collector may be expressed by

$$Q_u = \dot{m} C_p (T_o - T_i) \quad (1)$$

where \dot{m} is mass flow rate (kg/s)

Q_u - useful gain (W)

C_p - specific heat of the fluid at average temperature (J/kg°C)

T_o - T_i - outlet and inlet temperature of the collector (°C)

Equation (2) gives the expression for absorption of energy by the collector and losses to the surroundings. Under steady-state conditions, collector thermal performance may also be written as [6]

$$Q_u = A_c F_R [G_T (\alpha\tau) - U_L (T_i - T_a)] \quad (2)$$

where A_c - collector area (m²)

F_R - heat removal factor

G_T - instantaneous solar radiation (W/m²)

$(\alpha\tau)$ - the transmittance-absorptance product

U_L - collector overall energy loss coefficient (W/m²°C)

T_i and T_a - fluid inlet and ambient temperature (°C)

Instantaneous efficiency (η_i) of the collector is then expressed as

$$\eta_i = Q_u / A_c G_T = F_R (\tau\alpha) - [F_R U_L (T_i - T_a) / G_T] \quad (3)$$

$$\text{and } \eta_i = \dot{m} C_p (T_o - T_i) / A_c G_T \quad (4)$$

Assuming constant weather conditions and little difference in angle of incidence, the performance of a solar heating system can be characterized by the intercept and slope of η_i plotted against $(T_i - T_a) / G_T$. Because collector properties such as U_L , F_R , and $(\tau\alpha)$ are not constant with respect to time, the slope could otherwise be nonlinear.

Evaluations of efficiency are made based on symmetrical pairs, pairing data sets for before and after solar noon to minimize the effect of heat capacity of the solar collectors. Data are averaged for 30 minute periods. Instantaneous efficiencies are determined from equation (4) and plotted as a function of $(T_i - T_a) / G_T$. Aperture area (i.e., total cover area less the area of cover supports) is used to determine the efficiency of the collector.

The intercept with the Y-axis, or efficiency (η_i) coordinate, represents the $F_R(\tau\alpha)_n$ value for the tested solar collector and $F_R U_L$ is given by the slope of the graph. Mathematically $F_R U_L$ can be calculated as

$$F_R U_L = - \text{slope (graphically)}$$

$$F_R U_L = - (\eta_1 - \eta_2) / [((T_{i1} - T_{a1}) / G_{T1}) - ((T_{i2} - T_{a2}) / G_{T2})] \quad (5)$$

where η_1, η_2 - obtained efficiency before and after solar noon

T_{i1}, T_{a1} - inlet and ambient temperature of collector for first pair ($^{\circ}\text{C}$)

$T_{i2} - T_{a2}$ - inlet and ambient temperature of collector for second pair ($^{\circ}\text{C}$)

G_{T1}, G_{T2} - Instantaneous solar radiation (W/m^2)

Data from the collector testing are plotted as η_i vs. $(T_m - T_a) / G_T$, then the following formulas are used to convert the format.

$$F_R(\tau\alpha)_n = F_{\text{ext}}(\tau\alpha)_n [1 + (A_c F_{\text{ext}} U_L) / (2 \dot{m} C_p)]^{-1} \quad (6)$$

$$F_R U_L = F_{\text{ext}} U_L [1 + (A_c F_{\text{ext}} U_L) / (2 \dot{m} C_p)]^{-1} \quad (7)$$

where $T_{\text{av}} = (T_{\text{in}} + T_{\text{out}})/2$

T_{av} - average of inlet and outlet temperature (°C)

4.3.2 Calculation of values needed to determine efficiencies

4.3.2.1 Solar time

Most sun-angle relationships are based on solar time, which does not coincide with local time. To convert local time into solar time, two correction factors were used [6]:

- for the difference in longitude between the local longitude and the meridian on which the local time is based.
- the equation of time, which takes into account the effect of the rotation of the earth on the observer's meridian

$$\text{Solar time} - \text{Standard time} = 4 (L_{\text{st}} - L_{\text{loc}}) + E$$

where L_{st} - standard meridian for the local time zone

L_{loc} - longitude of the location

E - equation of time in minute and expressed as

$$E = 229.2 (0.000075 + 0.001868 \cos B - 0.032077 \sin B - 0.014615 \cos 2B - 0.04089 \sin 2B)$$

and $B = (n - 1) 360 / 365$ n = day of the year $1 \leq n \leq 365$

The standard meridian (L_{st}) for Calgary's time zone is 105°W (Mountain) and the longitude (L_{loc}) is 114°W.

4.3.2.2 Calculation of mass flow rate

The mass flow rate in a round duct is given by

$$\dot{m} = A \rho V$$

where A is area (m^2)

ρ is density at given pressure and temperature (kg/m^3)

V is average velocity (m/s)

4.3.2.2.1 Calculation of fluid density

According to the ideal-state gas law for air, the density of air is given by

$$\rho = P / RT$$

where ρ is the density of the air at given pressure and temperature

P is absolute pressure (Pa)

T is absolute temperature (°C)

R gas constant for the air (J/kgK)

In this formula, the density of the air (ρ) is taken as independent of the velocity and gauge pressure. The gauge pressure developed by the fluid flow is negligible compared to the barometric pressure.

The flow is considered to be incompressible, because of the very low Mach number [30]. The Mach number is the ratio of the velocity fluid in the pipe to the velocity of sound.

4.3.2.2.2 Calculation of average velocity

A hot wire anemometer was used to measure velocity in the ducts. After measuring the velocity at the center of the round duct, the logarithmic-law of velocity distribution was applied to calculate average velocity in the duct [31].

$$V = Q / A = \frac{1}{\pi R^2} \int_0^R u 2\pi r dr \quad (\text{m/s})$$

$$\text{where } u = u^* \left[\left(\frac{1}{k} \right) \ln \left(\frac{yu^*}{\nu} \right) + B \right] \quad (\text{m/s})$$

Where u^* is the friction velocity (m/s)

k, B - are constant and for turbulent flow values are 0.41 and 5 respectively

y - is the distance from the outer surface to the center (m)

ν - is the kinematic viscosity (m^2/s)

The friction velocity is given by

$$\frac{u_0}{u^*} = \frac{1}{0.41} + \ln \frac{R}{\nu} + 5$$

where u_0 is velocity at the center of the round duct.

4.4 Measurements to determine collector characteristics

System monitoring began in September 1996. Data were collected for September and October. Out of this data, only a few days data were chosen for further analysis, because only data for clear days could be used.

ASHRAE Standard 93-77 [32] was followed in selecting weather conditions for determining the solar air heater performance. The standard proposes that the

testing should be done for clear days to minimize the effect of diffuse radiation on the solar collector. In terms of radiation, the standard specifies that tests should be conducted for periods during which the 15-minute integrated average solar radiation is at least 630 W/m^2 .

In this study, south-facing vertical irradiation, wind speed, outside temperature, and barometric pressure were recorded at The University of Calgary. The data are recorded every minute.

4.4.1 Measuring instruments

4.4.1.1 Temperature measuring instruments

Electronic instruments (thermistor type) were used to read the temperature of the working fluid in the duct network of the solar system. Electronic microloggers (StowAway-XT) were programmed with Logbook software to measure temperature every minute. This instrument can store approximately 8000 values for approximately 5.5 days (for one minute measurement intervals). These data can be uploaded from the instrument to the computer using Logbook software. The maximum total error of these instruments ranges from 0.3 to 0.5 °C of full scale.

4.4.1.2 Velocity measuring instrument

The centre velocity of the inlet and outlet of the solar collector was measured with a Wallace Thermo-Anemometer, model No. GGA 23s. The centre velocities in outlet and inlet ducts were measured three or four times in every recording period (the solar system circulation fan has a constant speed, so very little change in velocity should occur). This instrument was calibrated in 1986 and the calibration certificate shows the maximum instrument error to

range from $\pm .33\%$ to $\pm 2\%$ (low range) or to $\pm 2.33\%$ (high range) of full scale. A few years ago, the anemometer was checked in the wind tunnel at the Department of Mechanical Engineering of the University of Calgary.

4.5 Assumptions for analysis

Because of limited access to the solar system duct network, efficiency and values such as $F_R(\tau\alpha)_n$, $F_R U_L$, were based on measurements for solar panels B, C, and D (see figure 3.1). These panels represent approximately 46 percent of the total collector area.

The overall collector efficiency is probably less than the one based on panels B, C, and D, because solar panels E and F (see figure 3.1) are triangular. This configuration reduces the contact period of the working fluid with the absorber plate. In other words, these configurations result in a shorter flow path for the working fluid than the rectangular panels. In this study, this effect could not be calculated, because the ducts to these panels were inaccessible.

4.6 Solar system test results

To eliminate errors due to the thermal constant of the solar collector, only radiation values higher than or equal to 600 W/m^2 were used for calculation of efficiency. The data show that the efficiency appears to rise in the afternoon even though the irradiation is very low, because of the thermal constant of the solar collector.

Tables 4.1a and 4.1b contain test results for October 3, 8, 9, 18, and 20, 1996. Thirty minute average values of the parameters and their corresponding efficiency values are shown in these tables.

Note that for the existing flow rate, the efficiency is strongly dependent on the ambient temperature and irradiation value, but varies little with wind speed.

Graphs of η_i vs. $(T_m - T_a) / G_T$ and η_i vs. $(T_i - T_a) / G_T$ are presented in figures 4.2 and 4.3 respectively. Each graph represents individual $F_R(\tau\alpha)_n$ and F_{RU_L} for a given testing day. Comparing these graphs, F_{RU_L} and $F_R(\tau\alpha)_n$ remain almost constant in different weather conditions. The F_{RU_L} value of Oct. 20 is an exception. Calculation of monthly utilizable solar energy for 1995 was based on average values of $F_R(\tau\alpha)_n$ and F_{RU_L} obtained from the testing.

October 3	T _o	T _i	T _w	T _a	G _T	\dot{m}	Q _b	η	$(T_w - T_o)/G_T$	Wind speed
time	°C	°C	°C	°C	w/m ²	kg/s	MJ/h			m/s
9:21	30.8	21.3	26.0	11.8	611	0.21	7.1	7.4	0.0234	2.3
10:51	36.4	21.5	29.0	14.1	725	0.20	10.9	9.5	0.0205	2.2
11:21	40.0	21.8	30.9	16.2	779	0.20	13.3	10.8	0.0189	2.1
11:51	42.8	22.0	32.4	17.8	827	0.20	14.9	11.4	0.0176	3.2
12:21	44.8	22.2	33.5	18.6	853	0.20	16.1	12.0	0.0175	3.4
12:51	47.7	22.7	35.2	19.5	862	0.20	17.6	13.0	0.0182	3.8
13:21	47.7	22.9	35.3	20.1	783	0.20	17.5	14.3	0.0194	3.4
13:51	47.1	23.1	35.1	20.3	665	0.20	17.0	16.7	0.0223	3.3
14:21	46.5	22.5	34.5	19.2	864	0.20	17.0	12.6	0.0178	3.9
October 9										
9:53	32.3	22.5	27.4	6.7	592	0.21	7.3	7.8	0.0349	0.6
10:23	36.8	22.6	29.7	8.7	679	0.20	10.4	9.8	0.0310	0.4
10:53	40.8	22.8	31.8	10.7	751	0.20	13.0	11.0	0.0281	0.2
11:23	43.6	22.9	33.3	12.8	807	0.20	14.9	11.7	0.0253	0.2
11:53	46.4	23.1	34.7	14.3	848	0.20	16.6	12.5	0.0240	0.4
12:23	48.9	23.3	36.1	15.3	874	0.20	18.1	13.2	0.0238	0.5
12:53	50.8	23.4	37.1	15.8	875	0.20	19.3	14.0	0.0244	0.6
13:23	51.7	23.5	37.6	16.1	864	0.20	19.8	14.6	0.0248	0.6
13:53	51.6	23.7	37.7	16.8	834	0.20	19.6	14.9	0.0251	0.5
14:23	50.9	23.9	37.4	17.2	784	0.20	19.0	15.4	0.0257	0.5
14:53	49.8	24.1	36.9	17.9	718	0.20	18.1	16.0	0.0265	0.5

Table 4.1a. Solar analysis data

October 18	T_o	T_i	T_a	G_T	\dot{m}	Q_u	η		Wind speed
time	°C	°C	°C	w/m ²	kg/s	MJ/h		$(T_i - T_a)/G_T$	m/s
9:51	27.7	20.8	5.0	632	0.20	5.1	5.0	0.0231	2.0
10:21	33.9	21.4	6.6	686	0.20	9.0	8.4	0.0189	2.1
10:51	38.5	21.6	7.8	787	0.20	12.1	9.7	0.0163	2.8
11:21	41.8	21.8	9.0	850	0.20	14.1	10.5	0.0141	4.3
11:51	44.1	21.9	10.0	902	0.20	15.5	10.9	0.0128	5.1
12:21	45.3	22.1	9.9	927	0.20	16.1	11.1	0.0132	5.7
12:51	44.2	22.3	9.7	928	0.20	15.3	10.5	0.0136	5.4
13:21	45.7	22.5	9.9	926	0.20	16.1	11.1	0.0140	5.7
13:51	42.4	22.7	10.3	901	0.20	13.9	9.8	0.0145	6.0
14:21	38.3	22.8	9.9	858	0.20	11.0	8.2	0.0162	6.4
14:51	32.5	22.8	9.9	793	0.20	7.0	5.6	0.0163	5.6
October 20									
9:51	18.5	2.0	-2.2	95	0.21	0.0	0.0	0.0619	12.0
10:21	19.4	2.1	-1.6	377	0.21	0.0	0.0	0.0293	9.0
10:51	20.1	2.8	-0.5	774	0.21	0.0	0.0	0.0249	7.0
11:21	23.9	4.3	0.7	845	0.21	2.5	1.8	0.0222	5.0
11:51	38.2	5.1	2.0	902	0.20	11.7	8.2	0.0215	3.0
12:21	43.3	5.7	4.2	922	0.20	14.8	10.2	0.0192	5.0
12:51	47.0	5.4	4.3	930	0.20	17.0	11.6	0.0197	6.0
13:21	44.9	5.7	4.6	923	0.20	15.4	10.6	0.0204	7.0
13:51	41.9	6.0	4.4	890	0.20	13.3	9.5	0.0222	7.0
14:21	47.5	6.4	4.6	836	0.20	16.7	12.7	0.0246	9.0
14:51	48.2	5.6	5.5	763	0.20	17.0	14.2	0.0237	11.0

Table 4.1b. Solar data analysis

Figure 4.2 shows graphs of η_i vs. $(T_{av} - T_a) / G_T$ based on average fluid temperature. $F_R(\tau\alpha)_n$ and $F_R U_L$ had values of 0.24 and 6.03 W/m² for Oct. 3 and 0.22 and 4.96 W/m² for Oct. 9.




Figure 4.2 Characteristic efficiency curves for the air heating flat-plate collector plotted as function of T_{av} .

Figure 4.3 shows graphs of η_i vs. $(T_i - T_a) / G_T$ based on inlet fluid and ambient temperature. $F_R(\tau\alpha)_n$ and $F_R U_L$ had values of 0.2 and 5.43 W/m² for Oct. 18 and 0.4 and 14.90 W/m² for Oct. 20. The value of $F_R U_L$ for Oct. 20 is not included in the average value.




Figure 4.3 Characteristic efficiency curves for the air heating flat-plate collector plotted as function of T_i .

The average values of $F_R(\tau\alpha)_n$ and $F_R U_L$ were 0.26 and 5.4 W/m² respectively. For solar energy utilizability calculations, $F_R(\tau\alpha)_n$ and $F_R U_L$ were taken as average values obtained from the experiment on the existing solar air heater.

4.7 Calculation of monthly useful solar energy

In this study, monthly average daily solar radiation was used to estimate the heat delivered by the solar air heater. To determine flat-plate collector

utilizability, a method proposed by Klein [33] was used. This method is called the daily $\bar{\phi}$ -chart method. The utilizable solar energy is defined as the fraction of incident solar radiation converted to useful heat.

The calculation steps are:

- determine \bar{H}_T , the monthly average daily radiation per unit area on the collector surface.
- determine R_n , the ratio of the radiation on the tilted surface to that on the horizontal surface at solar noon on the average day of the month.
- calculate utilizability coefficient $\bar{\phi}$ and monthly total energy collection by the solar heater.

4.7.1 Monthly radiation on the tilted surface

4.7.1.1 Monthly average daily extraterrestrial radiation

Monthly average daily extraterrestrial radiation (\bar{H}_0 , MJ/m²) for each month of the year is:

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
8.5	13.8	22.0	31.1	38.3	41.5	39.9	33.8	25.0	16.1	9.7	7.1

Table 4.2 Average daily extraterrestrial radiation

4.7.1.2 Monthly average daily radiation on the horizontal surface

Monthly average daily radiation on the horizontal surface (\bar{H} , MJ/m²) for 1995 meteorological data was:

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
4.9	5.6	13.4	15.9	20.7	21.0	19.4	19.5	15.3	9.0	4.6	3.7

Table 4.3 Daily radiation on horizontal surface

4.7.1.3 Monthly average clearness index

The monthly average clearness index \bar{K}_T (\bar{H} / H_0) for Calgary was:

Jan	Feb	Ma	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
.58	.41	.61	.51	.54	.51	.49	.58	.61	.56	.47	.52

Table 4.4 Clearness index

4.7.1.4 Calculation of sunset hour angles

Calculation of the sunset hour angle (ω_s) is given by expression:

$$\cos \omega_s = -\tan \phi \times \tan \delta$$

where ϕ - latitude of the location (51° for Calgary)

δ - solar declination

δ changes with mean day of the month and it is given by expression:

$$\delta = 23.45 \sin (360 \times (284+n) / 365)$$

where n - mean day of the month.

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
n	17	47	75	105	135	162	198	228	258	288	318	344
δ	-20.9	-13.0	-2.4	9.4	18.8	23.1	21.2	13.5	2.2	-9.6	-18.9	-23.0
ω_s	61.8	73.4	87.0	78.2	65.2	58.2	61.4	72.8	87.3	77.9	65.0	58.4

Table 4.5 Monthly values of n , δ , ω_s

4.7.1.5 Diffused component

Calculation of the beam and diffuse components of the monthly radiation for the mean day of the month is given by

$$\text{for } \omega_s \leq 81.4^\circ \text{ and } 0.3 \leq \bar{K}_T \leq 0.8$$

$$\bar{H}_d / \bar{H} = 1.391 - 3.56 \bar{K}_T + 4.189 \bar{K}_T^2 - 2.137 \bar{K}_T^3$$

$$\text{for } \omega_s > 81.4^\circ \text{ and } 0.3 \leq \bar{K}_T \leq 0.8$$

$$\bar{H}_d / \bar{H} = 1.311 - 3.022 \bar{K}_T + 3.427 \bar{K}_T^2 - 1.821 \bar{K}_T^3$$

where \bar{H}_d - diffused component of solar irradiation (J/m^2)

4.7.1.6 Average radiation on the tilted surface

Monthly mean solar radiation on the tilted surface for isotropic sky can be calculated from the expression:

$$\bar{H}_T = \bar{H} (1 - \bar{H}_d / \bar{H}) \bar{R}_b + \bar{H}_d \left[\frac{(1 + \cos \beta)}{2} \right] + \bar{H} \rho_g \left[\frac{(1 - \cos \beta)}{2} \right]$$

where $\frac{(1 + \cos \beta)}{2}$ - view factor to the sky F_{cs}

$\frac{(1 - \cos \beta)}{2}$ - view factor to the ground F_{cg}

ρ_g - diffuse reflectance of ground

β - sloped surface angle (degree)

4.7.1.7 Value \bar{R}

The average ratio of the total radiation on a tilted plane to that on the horizontal is given by

$$\bar{R} = \bar{H}_T / \bar{H} = (1 - \bar{H}_d / \bar{H}) \bar{R}_b + (\bar{H}_d / \bar{H}) \left[\frac{(1 + \cos \beta)}{2} \right] + \rho_g \left[\frac{(1 - \cos \beta)}{2} \right]$$

where \bar{H}_d / \bar{H} is a function of \bar{K}_T

4.7.1.8 Value \bar{R}_b

The ratio of the average daily beam radiation on the tilted surface to that on a horizontal surface for the month is \bar{R}_b and it is given by

$$\bar{R}_b = \bar{H}_{bT} / \bar{H}_b$$

or
$$\bar{R}_b = \frac{\cos(\phi - \beta) \cos \delta \sin \omega_s' + (\pi/180) \omega_s' \sin(\phi - \beta) \sin \delta}{\cos \phi \cos \delta \sin \omega_s + (\pi/180) \omega_s \sin \phi \sin \delta}$$

where ω_s' - sunset hour angle for the tilted surface of the mean day of the month

$$\omega_s' = \min [\cos^{-1}(-\tan \phi \tan \delta) \quad \cos^{-1}(-\tan(\phi - \beta) \tan \delta)]$$

where min means the smaller of the two items in the brackets

\bar{R}_{bT} - average daily beam radiation on tilted surface (J/m^2)

\bar{R}_b - average daily beam radiation on horizontal surface (J/m^2)

Table 4.6 presents results of the calculations.

Month	\bar{R}_h MJ/m^2	\bar{R}_b / \bar{R}_h	$1 - \bar{R}_b / \bar{R}_h$	ρ_g	\bar{R}_b	\bar{R}	\bar{R}_T MJ/m^2
Jan.	4.9	0.32	0.68	0.7	4.0	3.2	16
Feb.	5.6	0.49	0.51	0.7	2.5	1.9	10
Mar.	13.4	0.29	0.71	0.4	1.4	1.3	18
Apr.	15.9	0.38	0.62	0.4	0.8	0.9	14
May	20.7	0.35	0.65	0.2	0.5	0.6	12
Jun.	21.0	0.39	0.61	0.2	0.4	0.5	11
Jul.	19.4	0.40	0.60	0.2	0.5	0.6	12
Aug.	19.5	0.32	0.68	0.2	0.7	0.7	14
Sep.	15.3	0.29	0.71	0.2	1.1	1.0	16
Oct.	9.0	0.34	0.66	0.2	2.1	1.7	15
Nov.	4.6	0.42	0.58	0.4	3.5	2.4	11
Dec.	3.7	0.34	0.63	0.7	4.7	3.5	13

Table 4.6 Irradiation on the tilted surface of the solar collector based on 1995 weather data for Calgary

4.7.2 Useful solar energy calculation

4.7.2.1 Calculation of R_n

The ratio of radiation on the tilted surface to that on a horizontal surface at noon for an average day of the month (R_n) is calculated based on the individual components of solar radiation (i.e., beam, diffuse, and ground-reflected). Mathematically it is expressed as:

$$R_n = [(1 - (r_{d,n} / r_{T,n}) (H_d / H)) R_{bn}] + [(r_{d,n} / r_{T,n}) (H_d / H) ((1 + \cos\beta)/2)] + \rho_g [(1 - \cos\beta)/2]$$

where $r_{t,n}$ is the ratio of radiation at noon to the daily total radiation

$$r_{t,n} = r_{d,n} [1.07 + 0.025 \sin(\omega_s - 60)]$$

$r_{d,n}$ is the ratio of diffuse radiation at noon to the daily diffuse radiation

$$r_{d,n} = \pi / 24 [(1 - \cos\omega_s) / (\sin \omega_s - (\pi/180) \omega_s \cos\omega_s)]$$

$R_{b,n}$ - the ratio of beam radiation on the tilted surface to that on a horizontal surface at noon. For surfaces facing directly towards the equator:

$$R_{b,n} = (\cos (\phi - \beta) \cos \delta + \sin (\phi - \beta) \sin \delta) / (\cos \phi \cos \delta + \sin \phi \sin \delta)$$

4.7.2.2 Critical radiation level

The critical radiation level is defined as the irradiance at which the heat lost due to convection, conduction and radiation from the solar collector is equal to the heat produced by the collector. In other words, only radiation above this intensity (radiation level at tilted surface) will produce useful energy for space or water heating. The critical radiation level is defined as:

$$I_{TC} = \frac{F_R U_L (\bar{T}_{im} - \bar{T}_{amb})}{F_R (\bar{\tau} \bar{\alpha})} \quad (W/m^2)$$

where \bar{T}_{im} - average inlet temperature for the month ($^{\circ}C$)

\bar{T}_{amb} - average ambient temperature for the month ($^{\circ}C$)

4.7.2.3 Value \bar{X}_C

The ratio of the critical radiation to the radiation at noon for the average day during the month (on which the total radiation for the day is the same as the average for the month), \bar{X}_C , is given by

$$\bar{X}_C = I_{TC} / (r_{t,n} R_n \bar{H})$$

4.7.2.4 Calculation of utilizability coefficient $\bar{\phi}$

$\bar{\phi}$ is the fraction of the total radiation during the month which is above the critical radiation (I_c). The value of $\bar{\phi}$ for a one-month period depends upon the distribution of daily solar radiation.

$$\bar{\phi}_c = \exp \{ [a + b (R_n / \bar{R})] [\bar{X}_C + c \bar{X}_C^2] \}$$

where coefficients a , b and c are calculated as

$$a = 2.943 - 9.271 \bar{R}_T + 4.031 \bar{R}_T^2$$

$$b = -4.345 + 8.853 \bar{R}_T - 3.602 \bar{R}_T^2$$

$$c = -0.170 - 0.306 \bar{R}_T + 2.936 \bar{R}_T^2$$

4.7.2.5 Useful heat delivery

The total useful monthly energy output of a collector can be determined using the following expression:

$$Q_{\text{useful}} = A_c F_R (\bar{\tau}\alpha) \bar{\phi} \bar{H}_T N$$

where A_c is the area of the solar collector

$(\bar{\tau}\alpha)$ - average transmittance-absorptance product for the collector.

N - number of days in the month

Calculations were based on 1995 weather conditions. The parameters that are needed to determine the useful heat output of the solar collector are shown below. A summary of the calculated values is given in tables 4.7 and 4.8.

Slope of the collector = 90°

$F_{R(\alpha\tau)_n} = 0.264$ (average value of $F_{R(\alpha\tau)_n}$ from the collector testing)

$F_R U_L = 5.40 \text{ W/m}^2\text{C}$ (average value of $F_R U_L$ from the collector testing)

$(\alpha\tau)_n = 0.93 \cdot 0.9 \cdot 0.78 = 0.65$ (normal transmittance-absorptance product multiply by coefficient of angle of incidence for vertical position of the collector)

$F_R = 0.264 / 0.65 = 0.408$

Collector area = 95 m^2

Month	$(\bar{\tau}\alpha)$	$F_R(\bar{\tau}\alpha)$	$r_{d,n}$	$r_{t,n}$	R_n	$I_c \text{ W/m}^2$	\bar{X}_c	$\bar{\phi}_c$
Jan.	0.7	0.29	0.19	0.20	2.63	487	0.68	0.25
Feb.	0.7	0.28	0.16	0.17	1.68	489	1.10	0.16
Mar.	0.6	0.26	0.14	0.15	1.32	468	0.64	0.25
Apr.	0.6	0.25	0.15	0.16	0.95	369	0.55	0.35
May	0.6	0.23	0.18	0.20	0.69	245	0.31	0.56
Jun	0.5	0.22	0.20	0.21	0.62	146	0.19	0.71
Jul.	0.6	0.22	0.19	0.20	0.64	112	0.16	0.76
Aug.	0.6	0.24	0.16	0.17	0.79	149	0.21	0.70
Sep.	0.6	0.26	0.13	0.15	1.08	173	0.25	0.64
Oct.	0.7	0.27	0.15	0.16	1.47	296	0.50	0.39
Nov.	0.7	0.28	0.18	0.20	2.09	473	0.88	0.21
Dec.	0.7	0.28	0.20	0.21	2.78	583	0.97	0.15

Table 4.7 Calculation parameters for solar air heater analysis

	Out_temp	Degree Day	Monthly $Q_{utilizability}$	$Q_{utilizability}$ total	Q_{useful} gain
Month	To, C	°C	MJ/m2	GJ	GJ
Jan.	-6.0	774	123	12	3
Feb.	-5.0	671	47	4	1
Mar.	-2.2	653	138	13	3
Apr.	3.1	466	146	14	4
May	9.5	292	217	21	5
Jun	14.1	148	242	23	5
Jul.	15.4	107	276	26	6
Aug.	13.5	155	312	30	7
Sep.	11.8	209	300	28	7
Oct.	5.3	432	182	17	5
Nov.	-4.2	665	70	7	2
Dec.	-9.8	861	59	6	2
			Yearly total	201	50

Table 4.2.3.2 Useful solar heat gain for 1995

According to Mansour [29], solar gain is about 65 GJ per annual. In this study, annual heat gain from solar collector was found less than the previous study.

Major reasons of deviation in results are given below:

- different values for monthly incident radiation
- method of calculation

Low performance of the solar collectors is due to the following reasons:

- high heat loss from collectors
- low flow rate of working fluid
- low convective heat transfer between working fluid and absorber plate due to excessive air gap dimension
- shapes of the collectors

CHAPTER 5

COMPUTER SIMULATION MODEL OF THE CHURCH

This chapter details the application of the DOE-2 building energy simulation program [34] to the modeling of the church. It describes the program and its capabilities. An energy use analysis based on the DOE-2 simulation model for the building is presented.

5.1 The DOE-2 simulation program

The use of building energy analysis computer programs is becoming a standard procedure for estimating energy use in buildings. This is done to identify ways to design buildings or to modify existing buildings to be more energy efficient.

The DOE-2 program is an extremely large and complex computer program and it requires special knowledge on the part of users. It simulates the interaction of building systems in response to given conditions. These include the fabric, HVAC systems, and plant equipment. To obtain a completely correct model would require infinite detail, which would be impossible. Therefore, a level of abstraction must be selected that is adequate for calibration of the model.

DOE-2 is capable of detailed simulations of energy consumption in buildings. It comprises one translation program and four simulation subprograms. The translation program is called Building Description Language (BDL) processor. It translates user input into simulation code. The DOE-2 simulation

subprograms are called LOADS, SYSTEMS, PLANT, and ECONOMICS. A DOE-2 program flow chart is shown in figure 5.1.




Figure 5.1 DOE-2 program flow chart

5.1.1 DOE-2 subprograms

The LOADS program calculates peak loads and hourly space heating and cooling loads based on the indoor air temperature set for simulation. Results of the LOADS program are a function of ambient weather conditions, occupancy, lighting, infiltration of outside air, orientation of the building,

building shape, building materials, and miscellaneous internal loads. The LOADS program does not compute load due to ventilation of buildings.

The SYSTEMS program is capable of simulating the operation of secondary HVAC systems (e.g., fans, economizers, humidifiers) based on the results from the LOADS program and additional user-defined instructions regarding HVAC systems, ventilation quantity, equipment operation schedules and temperature and humidity set-points.

The PLANT program simulates the operation of the primary HVAC equipments (e.g., boiler, chillers, electrical generation equipment, specified solar heating and cooling systems) based on the results received from the SYSTEMS program and additional user-defined instructions. The program calculates the energy consumption by the equipment on an hourly basis.

The ECONOMICS analysis program calculates life-cycle cost of building components, and equipments based on capital costs and the utility rate structure defined by the user. In addition, it is capable of generating statistics for economic comparison of alternative approaches.

5.2 Data collection

The following five types of data were collected for the DOE-2 simulation:

- Data obtained from the construction documents and building plans, including building dimensions and material characteristics of walls, windows, roofs, and floors. Data on HVAC, lighting, and hot water systems and equipment were obtained from mechanical and electrical plans.

- **Data obtained by performing a visual inspection and interviews with facility staff: these include schedules, lighting control, control settings, occupancy levels, equipment operation and other human factors that are associated with energy use in the building.**
- **Data obtained from measurement and testing such as room temperature and energy contribution from the solar system.**
- **Data obtained from standards such as ventilation rates, infiltration rates etc.**
- **Data obtained from utility bills (e.g., natural gas and electricity consumption).**

5.3 Calibration of the DOE-2 model

The main purpose of the calibration of the DOE-2 model was to make a reference model that could be used as a base case for evaluation of later retrofitting options. The retrofitting options are detailed in Chapter 6.

To determine the accuracy of the simulation model for predicting future energy consumption (i.e., after retrofitting), it was essential to compare the results of simulation with building utility data. In using a building simulation model, both technical and occupant behaviors related to building energy consumption are very important. Often, occupant behaviors are difficult to study and to model, and this could make the simulation results different from the actual.

Calibration of the building model for analysis was done according to the flow chart shown in figure 5.2. Input data were obtained as described above. However, alteration in building operation or other factors that relate to energy consumption could affect the simulation results.

A complete DOE-2.1E model for the investigated building is presented in Appendix A3.




Figure 5.2 Flow chart of data analysis

5.4 Important assumptions to run DOE-2

- 20° C room temperature for winter.
- Free cooling during summer days.
- Air leakage according to ASHRAE Standard for tight building construction.
- Heat transfer to the ground through basement wall and basement floor at constant U-value. These values were taken from the ASHRAE Handbook of Fundamentals, 1981.
- Energy losses from ducts and pipes are negligible.
- Ventilation rate according to ASHRAE Standard 62-81.
- Weather data for 1995, the year for which gas and electricity use data were obtained.

5.5 Summary of building parameters

Summarized parameters set for the building simulation is given in table 5.1.

I. Building envelope

Area = 3,300 m²
 No. of floors = 3 floors
 Window U-values:
 single glazed = 6.2 W/m²C
 double glazed = 2.7 W/m²C
 triple glazed = 1.8 W/m²C
 Underg. wall U-value = 0.21 W/m²C
 Floor U-value = 0.13 W/m²C

II. Operating condition

Lighting density = 15 W/m²
 Room temperature = 20 °C
 Sp. relative humidity = min. 20 %

Occupancy heat gain:
 Offices/sanctuaries/school = 120 W
 Gymnasium/hall = 375 W

III. HVAC system and equipment

Constant volume system
 Perimeter radiation heating
 Ventilation:
 AHU-1 = 4.7 L/s/person
 AHU-2 and AHU-3 = 7.1 L/s/person
 Economizer cycle
 Natural gas-fired boiler

Table 5.1 Summary of building parameters

5.6 Data analysis and results

The results analysis is based on the calibrated model of the building. The energy consumption predictions for gas and electricity were compared with utility data. The results analysis includes building peak load components, comparison of metered and simulated monthly electricity and natural gas consumption, and annual energy consumption with solar system contribution.

5.6.1 Building peak load components

This report gives a breakdown of heating peak loads, according to the source of the load, for the building. It shows the amount of heat that must be added to the building per hour to maintain the air temperature set with the TEMPERATURE keyword in SPACE-CONDITIONS. Simulated values are for spaces that have been treated as conditioned spaces. The program excludes loads from unconditioned spaces such as the mechanical room and plenums. In addition, the program calculates building peak loads without ventilation. Building peak heating load components based on 1995 weather data are presented in the table 5.2.

Particulars	kW	kBTU/h
Wall conduction	-19.0	-65.2
Roof conduction	-11.0	-38.0
Window glass + frm. cond	-26.0	-88.4
Window glass solar	1.1	3.8
Door conduction	-2.2	-7.4
Underground surface cond	-5.5	-18.7
Occupants to space	0.5	1.8
Light to space	3.3	11.0
Equipment to space	0.2	0.5
Infiltration	-25.0	-85.0
Total	-84	-286

Table 5.2 Simulated building peak heating load components

The following paragraph describes particulars that have been used in the building peak load components (for heating only) :

- Wall conduction** - heat loss due to conduction through exterior walls
- Roof conduction** - heat loss due to conduction through roof areas
- Window glass+frm cond** - heat loss due to $UA\Delta T$ heat gain through all exterior windows (glass plus frames). It also includes solar energy absorbed by windows and frames and conducted into the space.
- Window glass solar** - heat gain caused by direct and diffuse solar radiation transmitted by the window glass.
- Door conduction** - heat loss due to conduction through exterior doors in the space.
- Underground surface cond** - heat loss due to the conduction through basement floors and the walls below grade.
- Occupants to space** - heat gain due to the occupants in the spaces.
- Light to space** - heat gain due to the lighting of the spaces.

- Equipment to space - heat gain due to the equipment in the spaces.
 Infiltration - heat loss due to the penetration of outside air.

Positive and negative signs in table 5.2 show whether heat is entering (+) or leaving (-) the space from corresponding components of the building.

Total load per unit area (excluding outside air ventilation load for the building) is approximately 30 W/m² (9.5 BTU/h m²).

5.6.2 Building energy performance summary

Table 5.3 presents annual building energy use according to energy type (e.g., electricity and natural gas) and category of use (area lighting, equipment, heating, and ventilation). This report (generated by DOE-2.1 E) is for 1995. It excludes the energy gain from the solar system.

REPORT - BEPS
 WEATHER FILE - CAL95.WYEC

ENERGY TYPE	Electricity, kWh	Natural gas, GJ
<u>Category of use</u>		
AREA LIGHTS	64476	0.
MISC EQUIPMT	5568	0.
SPACE HEAT	14654	1814
PUMPS & MISC	5861	0.
VENT FANS	53925	0.
DOHOT WATER	0.	303
TOTAL	144484	2118

TOTAL ELECTRICITY	144,484 kWh	48 kWh / m ²
TOTAL NATURAL GAS	2,118 GJ	0.7 GJ / m ²

Table 5.3 Simulated building energy summary for 1995

Brief description of categories of use in BEPS:

- | | |
|-------------------------|---|
| AREA LIGHTS | - electricity consumption associated with lighting. |
| MISC EQUIPMT | - electricity consumption associated with electric equipment. |
| SPACE HEAT | - electricity consumption of equipment whose primary purpose is heating and natural gas consumption to maintain the temperature set by users. |
| PUMPS & MISC | - electricity consumption of pumps and miscellaneous equipment. |
| VENT FANS | - electricity consumption by HVAC heating and exhaust fans. |
| DOMHOT WATER | - natural gas consumption of the hot water heater. |

5.6.3 Comparison of monthly simulation results with utility data

Figures 5.3 and 5.4 illustrate monthly simulated and metered data for 1995 natural gas and electrical energy consumption. The main purpose of these illustrations is to show the accuracy of the simulation model. See Appendix A3 for complete information on the DOE-2.1E input data. This type of comparison helps to evaluate the quality of the base case used in assessing retrofit options.




Figure 5.3 Simulated and metered natural gas consumption for 1995




Figure 5.4 Simulated and metered electrical energy consumption for 1995

Monthly deviations between predicted and measured data for electrical energy are smaller than for natural gas. The absolute difference between predicted and measured data for individual months ranged from 10 to 46 percent for natural gas, and from 3 to 15 percent for electricity, except June, July, and August because these months are not considered for space heating in the simulation. Despite the large differences for a few individual months, annual results show deviations of 13 and 9 percent for natural gas and electricity respectively.

Comparisons on a monthly basis show significantly higher deviations than the annual comparisons and it is probably due to following reasons:

- **Underpredictions in some months tend to compensate for overpredictions in other months, resulting in an improved annual comparison.**
- **The effect of the variations from standard schedules for parameters such as occupants, lights, and DHW tend to average out in the long-term annual results.**

In these simulation results, the solar contribution to building and hot water heating is not included. Assuming all heat gain from the solar system converts into energy to heat the building and water, the annual error of the simulation reduces from 13 to 11 percent for natural gas consumption.

CHAPTER 6

ENERGY SAVING OPTIONS

The purpose of this chapter is to present the concepts and procedures for retrofit programs for the building and to illustrate the benefit of such retrofits in terms of energy use. It contains results of an elimination parametrics analysis and a system retrofit study. At the end of this chapter, a possible retrofitting procedure to improve the performance of the solar system is presented.

6.1 Elimination parametrics

The elimination parametrics technique is used to determine the significant building energy systems parameters and their interaction. It is generally used during building design. However, the technique can also be used to evaluate major retrofit options. To compare effects on energy use of building parameters or components, a single parameter at a time is eliminated from the base case. If the energy use changes significantly, then the parameter needs to be considered carefully.

In this study, components such as ventilation, wall insulation, infiltration, and occupants were evaluated using elimination parametrics. These parameters were selected based on the simulation of energy use by the building (see Chapter 5). Figure 6.1 shows annual electricity consumption for the base building and for base building with each of the variables eliminated. Similarly, figure 6.2 shows results for natural gas consumption.




Figure 6.1 Simulated annual electricity consumption for the building, elimination parametrics




Figure 6.2 Simulated annual natural gas consumption for the building, elimination parametrics

Elimination parametrics results show that electrical energy consumption remains almost constant. Lighting and ventilation fans are the major loads for electricity consumption. On the other hand, natural gas consumption was significantly reduced with ventilation eliminated.

Viewing the results of the elimination parametrics analysis, it can be concluded that ventilation fans are the major load for electricity and heating of ventilation air is major use of natural gas.

6.2 Retrofit options

In the following subsections, results of retrofit simulations are presented for comparison of energy savings. Energy savings from retrofit measures are compared with the baseline energy use. This section focused on two retrofit measures and illustrates their potential to conserve energy.

6.2.1 Increase in wall insulation

This is a measure which is commonly recommended for buildings in cold climates. Originally, the building had R-11 wall insulation of fiberglass batts. To decrease the heat loss from the conduction through wall, wall insulation was doubled. Simulated energy use is presented in table 6.1.

ENERGY TYPE	Electricity, kWh	Natural gas, GJ
Category of use		
AREA LIGHTS	64476	0.
MISC EQUIPMT	5510	0.
SPACE HEAT	14009	1728
PUMPS & MISC	5627	0.
VENT FANS	53954	0.
DOHOT WATER	0.	303
TOTAL	143576	2031

TOTAL ELECTRICITY 143576 kWh 47.7 kWh / m²
 TOTAL NATURAL-GAS 2031 GJ 0.67 GJ / m²

Table 6.1 Simulated building annual energy use summary after thermal insulation retrofit

Figures 6.3 and 6.4 show the annual electrical and heating energy consumption of the modified design compared to the base case building.




Figure 6.3 Simulated annual electricity consumption: base case envelope and envelope with double insulation



Figure 6.4 Simulated annual natural gas consumption: base case envelope and envelope with double insulation

Electrical consumption remained almost the same, while natural gas consumption was reduced by 4 percent.

This retrofit idea would not be economically feasible because of the insignificant saving in total energy use.

6.2.2 Retrofit of heating systems

As mentioned earlier, spaces in the building have varying occupancy, especially in the Catholic and Lutheran sanctuaries (see Chapter 3). Both these sanctuaries are used very little compared with the other spaces on the same air-handling system (a single constant volume fan). About 24 percent of the area of the building is used for the Lutheran and Catholic sanctuaries. Therefore, separate zoning of the sanctuaries would reduce fan operation and allow reductions in heating of these spaces during unoccupied periods. The elimination parametrics studies show that ventilation fans consumed a large portion of total electricity use. These considerations show that a separate

HVAC system for the Catholic and Lutheran sanctuaries might give good results in total energy savings. Figure 6.5 shows the existing and retrofit option of HVAC system for the investigated building.

Retrofit of the HVAC system has been considered only for air-handling unit 1 (AHU-UNIT 1), which controls the zones shown in figure 6.5. In the existing system, all zones shown in the figure are controlled by a air-handling-unit (AHU-UNIT 1). In the retrofit model, these zones are separated; zones MZ4 and MZ5 (sanctuaries) are controlled by an individual air-handling unit. These changes were implemented in the simulation model. Detailed changes in the DOE-2 model are given in Appendix A4.

Other AHU-UNITs or HVAC heating systems for the spaces (AHU-UNIT 2 and AHU-UNIT 3) remained the same.




Figure 6.5 Retrofit HVAC system model

MZ4 - Main floor zone no. 4 (Catholic sanctuary)

MZ5 - Main floor zone no. 5 (Lutheran sanctuary)

MZ6 - Main floor zone no. 6 (Lobby)

MEZZ1 - Mezzanine floor zone no. 1 (Office)

MEZCZ - Mezzanine floor core zone (Service zone)

MEZCL1 & MEZCL2 - Mezzanine floor zone no. 4 (Class rooms)

Results of the retrofit are illustrated in figure 6.6 for electrical energy consumption.




Figure 6.6 Annual electricity consumption for the base case and system retrofit building

Comparing the annual electrical energy use with the base case model, the largest saving was found in ventilation (VENT FANS) followed by space heating (SPACE HEAT). The reductions in electrical energy consumption, as compared to the base case are 32 percent and 5 percent for VENT FANS and SPACE HEAT respectively. However, in PUMPS & MISC category, electrical consumption increased by 15 percent from the base case building.

Total electricity use is reduced by approximately 12 percent from the base case model.

These reductions in electricity use are primarily due to following reasons:

- fewer fan running hours for the sanctuaries
- reduction in fan power to circulate air during periods when the sanctuaries would be unoccupied.

The annual natural gas consumption for the base case and the retrofit building is illustrated in the figure 6.7.




Figure 6.7 Simulated annual natural gas consumption for the base case and system retrofit building

Simulation results show that the retrofit building consumed about 16 percent less natural gas energy than the base case building. The actual amount of reduction in natural gas is about 340 GJ per year.

These reductions in natural gas consumption are primarily due to following reason:

- temperature of the spaces is controlled by a space-specific occupancy schedule rather than with other zones as shown in figure 6.5.

NOTE: Simulation results would differ if the solar energy gains from the collector were considered. The solar heat gain from the collector (about 50 GJ/year) is not included here to simplify comparison.

6.3 Retrofit of the solar system parameters

This section details reasons for poor performance of the solar system. It describes procedures that would help to improve solar system performance. To determine the performance of the solar collector, the procedure suggested by Duffie and Beckman [6] is followed.

6.3.1 Factors governing performance

Generally the performance of the solar collector depends on parameters such as:

- Choice of materials (properties of material: α , τ , and ϵ)
- Ambient conditions (T_a , v_w , and G_T)
- Geometry of collector: length, height, and thickness of collector
- Flow rate: m (or G)
- Inlet temperature of working fluid, T_i
- Characteristics of the working fluid: C_p , λ , μ , and ρ

Kay's relation defined by Biondi et. al. [17] for the convective heat transfer coefficient inside an asymmetrical heated rectangular smooth duct and for fully developed turbulent flow is:

$$h_c = 0.0158 \lambda (GK / \mu)^{0.8} \quad (1)$$

where, mass flow rate per unit area $G = m / A$ (kg/s per m²)

geometric coefficient of collector $K = L / (bD_e)^{0.25}$ (m^{-0.25})

λ - air thermal conductivity (W/m°C)

μ - air dynamic viscosity (Pa × s)

h_c - convective heat transfer coefficient (W/m²°C)

L - length of the collector (m)

b - thickness of air flow channel (m)

D_e - (2 × b) equivalent diameter of the duct (m)

If λ and μ in equation (1) are treated as constant, h_c depends only on the product GK . Thus, the efficiency of the solar air heater is a function of these two parameters, if ambient conditions and material properties are considered constant.

The following calculation to determine the performance of the solar collector is based on:

- the recommended value for mass flow rate of air in rectangular ducts (i.e., 0.013 kg/s per m²) [35].
- reduction of the flow path to approximately one third of its original value, (i.e., 20 mm). However, optimum thickness of air flow channel is recommended to determine to obtain higher value of heat transfer coefficient and at the same time low power to drive required flow rate.

- each collector dimension is assumed as shown in figure 6.8.




Figure 6.8 Assumed collector dimension

6.3.2 Calculation of parameters needed to determine efficiencies

6.3.2.1 Top heat loss of the flat plate solar collector

It is very important to estimate heat losses from the collector plate. It is related to collector performance factors such as heat removal factor F_R , flow factor F' and efficiency of the collector η . In this particular case, heat lost from the back and the edge was ignored, because the temperature difference between the plate and building interior (the rear side of the solar collector is exposed to room temperature) is not great, especially when the back of the collector is insulated.

Heat lost due to the temperature difference and other factors such as wind, material emittance, number of cover plates and tilt angle were formulated by Klein [36]. The following model can be used to calculate top heat loss (U_i) within $\pm 0.3 \text{ W/m}^2\text{C}$ for general operating range of flat plate collector [6].

$$U_t = \left\{ \frac{n}{\frac{C}{T_{mp}} \left[\frac{(T_{mp} - T_a)^e}{(n+f)} \right]} + \frac{1}{h_w} \right\}^{-1} + \frac{\sigma \cdot (T_{mp} + T_a)(T_{mp}^2 - T_a^2)}{(\epsilon_p + 0.00591 \cdot n \cdot h_w)^{-1} + \frac{2 \cdot n + f - 1 + 0.133 \cdot \epsilon_p}{\epsilon_g} - n}$$

where,

n - number of glass covers

$f = (1 + 0.089 h_w - 0.116 h_w \epsilon_p)(1 + 0.07866 n)$

$C = 520 (1 - 0.000051 \beta^2)$, $\beta = 70^\circ$ for 90° tilt

$e = 0.430 (1 - 100/T_{mp})$

β - collector tilt (degree)

ϵ_p - emittance of plate

ϵ_g - emittance of the glass

T_a - ambient temperature (K)

T_{mp} - mean plate temperature (K)

h_w - wind heat transfer coefficient ($W/m^2 \text{ } ^\circ C$)

The major problem in solving this equation is the absorber plate temperature, which is a function of factors such as the collector design, the incident solar radiation, entering fluid temperature and ambient temperature. For design purposes, the plate temperature is taken as constant, whereas in practice it changes with the length of the plate.

6.3.2.2 Radiation heat transfer coefficient in rectangular duct of solar collector

The radiation coefficient between the two duct surfaces, assuming mean radiant temperature equal to mean fluid temperature, is estimated as:

$$h_r = \frac{4\sigma \bar{T}^3}{(1/\varepsilon_1) + (1/\varepsilon_2) - 1} \quad (\text{W/m}^2 \text{ } ^\circ\text{C})$$

where, σ - Stefan-Boltzmann constant

\bar{T} - main fluid temperature (K)

$\varepsilon_1, \varepsilon_2$ - plate emittance

6.3.2.3 Reynolds number

To determine flow characteristic, the Reynolds number at an assumed average fluid temperature is given by:

$$Re = \dot{m} D_e / A_f \mu$$

where, D_e - equivalent diameter (m)

A_f - fluid flowing area (m^2)

\dot{m} - mass flow rate (kg/s)

6.3.2.4 Collector efficiency factor

The collector efficiency factor does not vary much with operating conditions, so it is treated as constant in practice [16]. It shows how effectively heat is transferred from the absorber surfaces to the working fluid. Mathematically it is expressed as:

$$F' = \left[1 + \frac{U_t}{h_c + \left[\left(\frac{1}{h_c} \right) + \left(\frac{1}{h_r} \right) \right]^{-1}} \right]^{-1}$$

where, U_t - top heat loss coefficient ($\text{W/m}^2 \text{ } ^\circ\text{C}$)

h_c - convective heat loss coefficient (W/m²°C)

h_r - radiative heat loss coefficient (W/m²°C)

6.3.2.5 Collector flow factor

The collector flow factor is a function of a dimensionless collector capacitance rate $\dot{m} C_p / A_c U_t F'$. Mathematically it is expressed as:

$$F' = \dot{m} C_p / A_c U_t F' [1 - \exp (- A_c U_t F' / \dot{m} C_p)]$$

where, C_p - specific heat of air (J/kg°C)

6.3.2.6 Heat removal factor

The heat removal factor is a function of the fluid flow rate and the absorber plate design (thickness, material properties). It is nearly independent of solar radiation intensity and ambient and collector plate temperature.

Mathematically it is expressed as:

$$F_R = F' F''$$

6.3.2.7 Useful energy gain

Maximum useful energy collected by the collector Q_u , is given by

$$Q_u = A_c F_R [I_T - U_t (T_i - T_a)] \quad (W)$$

where, I_T - incident radiation (W/m²)

6.3.2.8 Mean plate and fluid temperature

Theoretically mean plate temperature is expressed as:

$$T_{mp} = T_i - (Q_u / A_c) / (F_R U_l) (1 - F_R) \quad (^\circ\text{C})$$

Theoretically mean fluid temperature is expressed as:

$$T_{mf} = T_i - (Q_u / A_c) / (F_R U_l) (1 - F_R'') \quad (^\circ\text{C})$$

An iteration process is necessary if initial temperature estimates are found to differ from the values obtained from the above equations.

6.3.3 Efficiency

Efficiency of the air heater can be calculated as:

$$\eta = Q_u / A_c I_T$$

6.3.3.1 Summary of the efficiency calculation

An initial mean fluid temperature of 33 °C (306 K) and mean plate temperature of 50 °C (323 K) were assumed for calculation. Ambient temperature and radiation on the tilted surface were taken from table 4.1 (see Chapter 4) to allow performance comparisons. All air properties are based on mean fluid temperature.

A summary of calculated parameters is provided in the first row of table 6.2. To evaluate assumed initial plate temperature, iterations were performed. Results of the iteration process also presented in the second row of table 6.2.

Table 6.2 shows that parameters do not change much with a few degrees difference in plate temperature. Calculated parameters given in table 6.2 are based on a radiation value of 600 W/m^2 .

	h_c	Re	h_r	U_t	F'	F''	Q_u	T_{mp}	T_{mf}
	8	4216	5.3	5.4	0.67	0.87	630	46	28
Iteration	8	4216	5.1	5.3	0.67	0.88	632	47	28

Table 6.2 Parameters to determine efficiency of the solar collector (based on incident radiation of 600 W/m^2)

Similar calculations were performed for incident radiation of 900 W/m^2 to determine efficiency of the "modified" collector.

For comparison purposes, performance of the existing solar collector (see Chapter 4) and "modified" solar collector are presented in table 6.3 for two different levels of solar radiation.

Radiation level (W/m^2)	Efficiency of the existing solar system	Efficiency of the "modified" solar system
600	7 %	35 %
900	16 %	38 %

Table 6.3 Efficiency of the solar collectors (existing and retrofit)

Results show that the efficiency is determined by the major factors mentioned above. Using this type of retrofit, the solar collector performance could be increased from the existing conditions by 5 to 2.4 times for low and high incident radiation respectively. In addition, results show that these factors are more sensitive to solar collector output at low radiation levels.

CHAPTER 7

CONCLUSIONS AND RECOMMENDATIONS

7.1 Summary of work completed

This study has fulfilled the major objectives of the research which were: 1) to evaluate the performance of the building-integrated solar air heating system in a church building, and 2) to evaluate other energy conservation alternatives relative to the solar heating option. A literature review of basic factors that govern building energy use, of factors that affect the performance of solar air heaters, and on the performance and validation of the DOE-2 building energy simulation program was conducted.

To increase accuracy in simulation and evaluation of the solar air heating system, an hourly weather file was prepared for Calgary for 1995.

To determine the fundamental characteristics (such as $F_R U_L$, $F_R(\tau\alpha)$) of the solar air heater, its thermal efficiency was determined by testing. Thereafter, these coefficients were used in calculation of monthly heating contribution (i.e., building and domestic hot water) of the solar air heater. The daily utilizability method proposed by Klein [33] was used to calculate solar contribution.

The DOE-2 building energy simulation program was used to analyze energy use in the building. Simulation results were compared with 1995 utility data obtained from the building administration. The DOE-2 model was calibrated to create a base case to which energy conserving retrofits could be compared.

Based on the calibrated simulation model, two retrofit options (i.e., increase in wall insulation and retrofit of heating system) were simulated for comparison of energy savings.

For theoretical analysis of the solar collector retrofit, procedures suggested by Duffie and Beckman [6] and Biondi et. al. [17] were used.

7.2 Summary of results and conclusions

7.2.1 Results and conclusions on the existing solar air heating system

The total contribution of the solar air heater was found to be about 50 GJ/year.

Tests revealed that the efficiency of the solar system at lower levels of radiation, for example 600 W/m^2 , was only about 7 percent and for high radiation levels, for example 900 W/m^2 , about 17 percent. Major reasons for poor performance of the solar air heater under existing conditions are as follows:

- The actual flow rate of the working fluid is lower than the design value.
- There must be some air leaks or obstructions in the solar air flow channels, which was confirmed by the measured inlet and outlet air velocities in the duct network.
- The air flow channel behind the absorber plate was too deep.
- The specific flow rate is much lower than recommended values.

- Improper operation of the control system (during investigation period; the solar air circulating fan was found running in the evening at 7.30 PM, when outside radiation was almost zero).
- Shape of the solar collector.
- Long ducting network (masonry wall for thermal storage is far from the solar collector panels)

7.2.2 Results and conclusions of retrofit options

The analysis of retrofit options provided a better understanding of energy use and revealed a large potential for energy conservation in buildings like the Sandstone Valley Ecumenical Centre.

Commonly recommended measures such as an increase in wall insulation may not be economically attractive. Simulated results showed that increasing wall insulation by double, did not affect electricity consumption and reduced natural gas consumption by only 4 percent.

Division of the large central system into a few systems sharing with more diverse operating, permits large savings in total energy use. Simulated results showed that, by implementing such a retrofit, total electricity use was reduced by approximately 12 percent and natural gas use was about 16 percent from the base case. The actual reduction for natural gas was about 340 GJ/year and for electricity about 17000 kWh/year.

From these results it can be seen that this option would provide a lower rate of energy consumption for the investigated building.

Solar collector parameters such as air gap and specific flow rate of the working fluid significantly influenced performance. Calculated results showed that decreasing the air gap by one-third and providing recommended flow rate of 11 l/s would increase the performance of the solar collector by 5 times under low levels of radiation and 2.7 times under high levels of radiation.

7.3 General conclusions

Solar air heating systems might not be feasible for places like Calgary where natural gas is relatively cheap. However, better design of the collectors and other associated features of the solar air heating system would permit thermal energy at a much lower cost than the existing systems.

Ventilation represents a major building heating load in a cold climate.

When designing buildings energy systems, building components and HVAC systems should be analyzed with simulation tools like DOE-2 to identify energy saving options.

7.4 Recommendation for future work

Due to complex factors of energy use and limited analysis tools were used to accomplish the defined tasks, following future works will help to improve the obtained results to this study.

- Life-cycle costing of the retrofit solar system should be carried out.
- Life-cycle cost analysis should be performed for the system retrofits that were modeled.

- **A solar air heater simulation algorithm could be developed for the DOE-2 program. This would allow the concept to be evaluated for a wide range of climates.**

References

1. Kreider, J.F. and A. Rabl, 1994. Heating and Cooling of Buildings: Design for Efficiency. McGraw-Hill Inc., NY.
2. Chiogioji, M.H. and E.N. Oura, 1982. Energy Conservation in Commercial and Residential Buildings, Marcel Dekker Inc., N.Y.
3. Stein, B. and J.S. Reynolds, 8th edition, 1992. Mechanical and Electrical Equipment for Buildings. John Wiley & Sons Inc., N.Y.
4. Dixon, A.E. and J.D. Leslie, 1978. Solar Energy Conversion: An Introductory Course. Pergamon Press, Toronto.
5. Lee, T.G., 1985. Active Charge/Passive Discharge in a Structural Masonry Wall. Sunworld, International Solar Energy Society, Victoria, Australia, Vol. 8.
6. Duffie, J.A. and W.A. Beckman, 2nd Edition, 1991. Solar Engineering of Thermal Processes. John Wiley & Sons Inc., NY.
7. Johnson, C.A. and R.W. Besant, 1993. Economic Analysis of Daylit and Nondaylit Office Buildings in Canada. ASHRAE Transactions, Vol.99, Part 2.
8. Hunn, B.D., M.M. Grasso, J.W. Jones, and J.D. Hitzfelder, 1993. Effectiveness of Shading Devices on Building in Heating-dominated Climate. ASHRAE Transactions, Vol. 99, Part 2.
9. ASHRAE, 1981. ASHRAE Standard 62-81: Ventilation for acceptable indoor air quality. American Society of Heating and Refrigerating, and Air-Conditioning Engineers, Inc., Atlanta, GA
10. ASHRAE, 1989. ASHRAE Standard 90.1-1989: Ventilation for acceptable indoor air quality. American Society of Heating and Refrigerating, and Air-Conditioning Engineers, Inc., Atlanta, GA
11. Roose, R.W., 1978. Handbook of Energy Conservation for Mechanical Systems in Buildings. Van Nostrand Reinhold company, N.Y.
12. Eto, J.H. and C. Meyer, 1988. The HVAC Cost of Fresh Air Ventilation. ASHRAE Journal, September.

13. **Shavit, G. and W. Richard, 1993. Energy Conservation and Control Strategies for Integrated Lighting and HVAC Systems, ASHRAE Transactions, Vol.99, Part 2.**
14. **C2000 Program for Advanced Commercial Buildings, Program Requirements, 1993, CANMET, Natural Resources Canada, Oct. 15.**
15. **ASHRAE/IES Standard 90.1-1989, 1989. Energy Efficient Design of New Buildings Except Low-Rise Residential Building. ASHRAE Inc., Atlanta, GA.**
16. **Francis de Winter, Editor, 1990. Solar Collector Storage, and Materials. The MIT Press, Cambridge, Massachusetts, London.**
17. **Biondi, P., L. Cicala and G. Farina, 1988. Performance Analysis of Solar Air Heaters of Conventional Design. Solar Energy, Vol. 41.**
18. **Close, D.J. and M.B. Yusoff., 1977. The Effects of Air Leaks on Solar Air Collector Behavior. Solar Energy, Vol. 20.**
19. **Mustafa, M.E., 1989. Optimum Orientation of Absorber Plates. Solar Energy, Vol. 42.**
20. **Grag, H.P., 1974. Effect of Dirt on Transparent Covers in Flat-Plate Solar Energy Collectors. Solar Energy, Vol. 25.**
21. **Roger, H.B., A.S. Hirshberg and W.H. Babcock, 1979. Economic Feasibility of Solar Water and Space Heating. Science, Vol. 203.**
22. **Kusuda, T., I. Sud, and T. Alereza, 1981. Comparison of DOE-2-Generated Residential Design Energy Budgets with Those Calculated by the Degree-Day and Bin Methods. ASHRAE Transactions, Vol. 87, Part 1.**
23. **Diamond, S.C and B.D. Hunn, 1981. Comparison of DOE-2 Computer Program Simulations to Metered Data for Seven Commercial Buildings. ASHRAE Transactions, Vol. 87, Part 1.**
24. **Diamond, S.C., B.D. Hunn and C.C. Cappiello, 1985. The DOE-2 Validation. ASHRAE Journal, November.**

25. DOE-2.1E, Version 2.1E, 1993. User's guide. Lawrence Berkeley Laboratory, Berkeley, CA.
26. ASHRAE, 1989. Handbook of Fundamentals. ASHRAE, Atlanta, GA.
27. McQuiston, F.C. and J.D. Parker, 3rd Edition 1988. Heating Ventilation, and Air-Conditioning: Analysis and Design. John Wiley & Sons, NY.
28. ASHRAE, 1981. Handbook of Fundamentals. ASHRAE, Atlanta, GA.
29. Mansour, T.N., 1990. Evaluation of the Solar Hybrid System at the Sandstone Valley Ecumenical centre. Energy, Mines and Resources Canada, Contract file No. CN 7909-X-X.
30. ASHRAE, 1977. Handbook of Fundamentals. ASHRAE, New York.
31. White, F.M., 3rd Edition, 1994. Fluid Mechanics. McGraw-Hill Inc., New York.
32. ASHRAE, Standard 93-77, 1977. Methods of Testing to Determine the Thermal Performance of Solar Collectors. ASHRAE, New York.
33. Klein, S.A., 1978. Calculation of Flat-plate Collector Utilizability. Solar Energy, Vol. 21.
34. DOE-2.1E, Version 2.1E, 1993. Reference Manual. Lawrence Berkely Laboratory, Berkeley, CA.
35. Lee, T.G., 1991. Solar Heat Storage: Using concrete block walls. Canadian Masonry Contractor, September.
36. Klein, S. A., 1975. Calculation of Flat-Plate Loss Coefficients. Solar Energy, Vol. 17.

Appendix A1

Wall constructions:

Basement

- wall construction (below the ground level); 250 mm concrete foundation wall, fir studs of 38x140 mm @ 406 mm O.C.D., 89 mm (3.5 in.) insulation batt, polyethelene vapor barrier, and 25.9 mm drywall with interior finish.
- wall construction (above ground level); 90 mm brick, 25 mm air space, building paper, 12 mm plywood, fir studs of 38x140 mm @ 406 mm O.C.D., 89 mm (3.5 in.) insulation batt, fir studs of 38x140 mm @ 406 mm O.C.D., 89 mm (3.5 in.) insulation batt, vapor barrier, and 15.9 mm drywall with interior finish.

Main floor

- wall construction (above ground level); 90 mm brick, 25 mm air space, building paper, 12mm plywood, fir studs of 38x140 mm @ 406 mm O.C.D., 89 mm (3.5 in.) batt insulation, vapor barrier, 15.9 mm drywall with interior finish. Some sanctuary walls have extra brick construction of 90 mm facing inside the building and these are up to the valence.

Curtain wall

- wall construction (solar panel) : single-glazed tempered glass, air gap, sheet metal absorber plate, air gap (air flow channel), 38 mm rigid

fiberglass insulation, fir studs of 38x140 mm @ 406 mm O.C.D., 89 mm (3.5 in.) batt insulation, and 15.9 mm drywall.

Roof constructions:

- **roof construction (sanctuary):** concrete roof tiles, 19x38 mm wooden strap in parallel and in perpendicular direction @ max 345 and 300 mm respectively, 350 mm nonregular cemented lap, 16 mm plywood sheathing, 178 mm (7 in.) insulation batt, vapor barrier, 12.7 mm gyption board. air space for ducting, and 12.7 mm veneer plywood ceiling.
- **roof construction (gym/hall and administration):** concrete roof tiles, 19x38 mm wooden strap in parallel and in perpendicular direction @ max 345 and 300 mm respectively, nongranular 350 mm cemented lap, 16 mm plywood sheathing, 178 mm (7 in.) batt insulation, vapour bassier, and 15.9 mm gypsum board.

Appendix A2

Building HVAC system and equipment

Capacity and specification of AHU units:

No.	Manufact	Model	Type	Capacity (L/s)	St.press. kPa	HP
AHU-1	TRANE	Climate Changer #21	Low press.	5000	0.560	7.5
AHU-2	TRANE	Climate Changer #10	Low press.	2250	0.560	5.0
AHU-3	TRANE	Climate Changer #8	Low press.	2000	0.187	1.5

Capacity and specification of AHU (air handling unit)

Capacity and specification of exhaust fans:

No.	Manufact.	Model	Capacity (L/s)	St. press. kPa	HP
EXH-1	GREENHECK	DSQ-120-A	830	0.1	1/3
EXH-2	GREENHECK	DSQ-95-G	250	0.02	1/15
EXH-3	GREENHECK	CSP-15	50	0.05	1/150
EXH-4			30	0.02	

Capacity and specification of Exhaust fans

Capacity and specification of boiler:

Boiler No.	MFG.	Model	Cap. (kW)	Gas flow rate (m ³ /hr)		Thermal	
				Stage 1	Stage 2	Stage	Stage
1	Superhot	AAE-1080-N-M	316	15.11	14.01	79.8	81.7
2	Superhot	AAE-1080-N-M	316	16.28	11.880	79.7	80.4

Heating boiler capacity and specification**Capacity and specification of Domestic Water Heater (DWH):**

Heater No.	MFG.	S/N	Capacity	flow rate (m ³ /hr)	Thermal Efficiency
DWH 1	Superhot	DA5891703	95	8.83	74.6
DWH 2	Superhot	DA5891700	95	9.42	73.4

DWH capacity and specification

INPUT LOADS ..

ABORT ERRORS ..
DIAGNOSTIC WARNINGS ..
RUN-PERIOD JAN 1 1995 THRU DEC 31 1995 ..
LOADS-REPORT SUMMARY=(LS-C) ..

\$--BUILDING LOCATION--\$

BUILDING-LOCATION

LAT=51 LON=114
ALT=3540 T-Z=7
HOL=YES
AZ=0

GROSS-AREA=32615 ..
ALT-HOLIDAYS=JAN 1 APR 14 MAY 22 JUL 1 AUG 7 SEP 4 OCT 1
NOV 11 DEC 25 DEC 26 ..

\$---BUILDING DESCRIPTION---

\$--CONS TYPES--\$

\$--WALL-EXTERIOR--\$

DRYWALL=MAT	TH=0.0417	COND=0.0925	DENS=50	S-H=0.26 ..
				\$1/2"DRYWALL
RINSUL=MAT	TH=0.583	COND=0.025	DENS=60	S-H=0.2 ..
				\$7"INSULATION BATT

WALL-TYPE1=LAYERS

MAT=(BK05,AL21,BP03,PW03,IN02,BP03,DRYWALL)
I-F-R=0.68 ..

WALL-TYPE2 = LAYERS

MAT= (BK05,AL21,BP03,PW03,IN02,BP03,BK05)

I-F-R=0.68 ..

SSANCTUARY'S WALLS UPTO VALANCE

WALL-TYPE 10-LAYERS

MAT=(BK05.AL21.BP03.PW03.IN02.IN02.BP03.DRYWALL)

 $I-F-R=0.68$..

SRECCENTRE'S WALLS

WALL3=CONS U=0.037 .. \$UNDERGROUND WALLS
 WALL1=CONS LAYERS=WALL-TYPE1 ABS=.88 ..
 WALL2=CONS LAYERS=WALL-TYPE2 ABS=.88 ..
 WALL10=CONS LAYERS=WALL-TYPE10 ABS=.88 ..

\$---WALL-INTERIOR---\$

WALL5=CONS U=0.32 .. \$GENERAL
 WALL6 = CONS U=2.7 .. \$NONEXISTING PARTITION
 WALL-TYPE7 =LAYERS MAT=(BK02) ..
 WALL-TYPE8 =LAYERS MAT=(BK01,AL11,GP01) ..
 WALL7=CONS LAYERS=WALL-TYPE7 ABS=.88 ..
 WALL8=CONS LAYERS=WALL-TYPE8 ABS=.88 ..

\$---FLOOR---\$

FLOOR-TYPE1=CONS U=0.023 .. \$UNDERGROUND
 FLOOR-TYPE2 = CONS U=0.2 .. \$MAIN AND MEZZANINE

\$---ROOF---\$

ROOF-TYPE1 = LAYERS
 MAT=(CC32,AL33,PW04,RINSUL,BP03,GP02) I-F-R=0.68 ..

\$ROOF OF THE BUILDING OTHER THAN

SANCTUARY
 ROOF2=CONS U=1.05 .. \$SKYLIGHT ROOF
 ROOF-TYPE3=LAYERS
 MAT=(CC32,AL33,BP01,PW04,RINSUL,BP03,GP01,PW03) I-F-R=0.68 ..

\$L/C ROOFING MATERIALS

ROOF1=CONS LAYERS=ROOF-TYPE1 ABS=.85 RO=3 ..
 ROOF3=CONS LAYERS=ROOF-TYPE3 ABS=.85 RO=3 ..

\$---WI GLASS-TYPE---\$

GL-TYPE1= G-T G-T-C=2004
 SPACER-TYPE-CODE=1 .. \$WALL WI GLASS
 GL-TYPE2= G-T G-T-C=3002
 SPACER-TYPE-CODE=1 .. \$ATTIC

DRGL-TYPE3=G-T G-T-C=1001
 SPACER-TYPE-CODE=1 .. \$ GLASS DOOR

\$---DOOR---\$

DR=CONS U=.629 ABS=.78 ..

§--OCCUPENCY SCHEDULES--§

OFF-OCC1=D-SCH	(1,8)(0)(9,13)(1)(14,24)(0) ..
OFF-OCC2=D-SCH	(1,24)(0) ..
OFF-OCC=W-SCH	(MON,FRI) OFF-OCC1
	(WEH) OFF-OCC2 ..
OFF-OCC-SCH=SCH	THRU DEC 31 OFF-OCC ..
ADM-OCC1=D-SCH	(1,7)(0)(8,18)(1)(19,22)(0.5)
	(23,24)(0) ..
ADM-OCC2=D-SCH	(1,13)(0)(14,18)(0.5)(19,24)(0) ..
ADM-OCC3=D-SCH	(1,8)(0)(9,15)(0.5)(16,24)(0) ..
ADM-OCC4=D-SCH	(1,24)(0) ..
ADM-OCC=W-SCH	(MON,FRI) ADM-OCC1 (SAT) ADM-OCC2
	(SUN) ADM-OCC3 (HOL) ADM-OCC4 ..
ADM-OCC-SCH=SCH	THRU DEC 31 ADM-OCC ..
GYM-OCC1=D-SCH	(1,8)(0)(9,13)(1)(14,15)(0.3)
	(16,18)(1)(19,24)(0) ..
GYM-OCC2=D-SCH	(1,24)(0) ..
GYM-OCC=W-SCH	(MON,FRI) GYM-OCC1
	(WEH) GYM-OCC2 ..
GYM-OCC-SCH=SCH	THRU DEC 31 GYM-OCC ..
L/OCC1=D-SCH	(1,24)(0) ..
L/OCC2=D-SCH	(1,9)(0)(10,11)(1)(12,24)(0) ..
L/OCC-SCH=W-SCH	(MON,SAT) L/OCC1 (SUN,HOL) L/OCC2 ..
L/SANCT-OCC-SCH=SCH	THRU DEC 31 L/OCC-SCH ..
C/OCC1=D-SCH	(1,24)(0) ..
C/OCC2=D-SCH	(1,17)(0)(18,19)(1)(20,24)(0) ..
C/OCC3=D-SCH	(1,8)(0)(9,10)(1)(11,24)(0) ..
C/OCC4=D-SCH	(1,6)(0)(7,8)(1)(9,24)(0) ..
C/OCC5=D-SCH	(1,13)(0)(14,15)(1)(16,18)(0)(19,24)(0) ..
C/OCC6=D-SCH	(1,8)(0)(9,13)(1)(14,24)(0) ..
C/OCC-SCH=W-SCH	(MON) C/OCC1 (TUE) C/OCC2
	(WED) C/OCC3 (THU) C/OCC4
	(FRI) C/OCC4 (SAT) C/OCC5
	(SUN) C/OCC6 (HOL) C/OCC1 ..
C/SANCT-OCC-SCH=SCH	THRU DEC 31 C/OCC-SCH ..
ED/CL-OCC1=D-SCH	(1,8)(0)(9,15)(1)(16,24)(0) ..
ED/CL-OCC2=D-SCH	(1,8)(0)(9,15)(1)(16,24)(0) ..
ED/CL-OCC3=D-SCH	(1,24)(0) ..
ED/CL-OCC=W-SCH	(MON,FRI) ED/CL-OCC1
	(SAT) ED/CL-OCC2
	(SUN,HOL) ED/CL-OCC3 ..
ED/CL-OCC-SCH=SCH	THRU DEC 31 ED/CL-OCC ..

SCHOOL-OCC1=D-SCH	(1,6)(0)(7,10)(1)(11,24)(0) ..
SCHOOL-OCC2=D-SCH	(1,8)(0)(9,11)(1)(12,24)(0) ..
SCHOOL-OCC3=D-SCH	(1,24)(0) ..
SCHOOL-OCC=W-SCH	(MON,FRI) SCHOOL-OCC1
	(SUN) SCHOOL-OCC2
	(SAT) SCHOOL-OCC3
	(HOL) SCHOOL-OCC3 ..
SCHOOL-OCC-SCH=SCH	THRU DEC 31 SCHOOL-OCC ..
NUR-OCC1=D-SCH	(1,8)(0)(9,13)(1)(14,18)(0)(19,21)(1)(22,24)(0) ..
NUR-OCC2=D-SCH	(1,24)(0) ..
NUR-OCC=W-SCH	(MON,FRI) NUR-OCC1 (WEH) NUR-OCC2 ..
NUR-OCC-SCH=SCH	THRU DEC 31 NUR-OCC ..

§—LIGHTING SCHEDULE—§

OFF-LT1=D-SCH	(1,8)(0)(9,13)(1,9,9,9,9)(14,24)(0) ..
OFF-LT2=D-SCH	(1,24)(0) ..
OFF-LT=W-SCH	(MON,FRI) OFF-LT1 (WEH) OFF-LT2 ..
OFF-LT-SCH=SCH	THRU DEC 31 OFF-LT ..
AD-LT1=D-SCH	(1,7)(1)(8,17)(9,9,9,9,5,5,5,8,8,9)
	(18,22)(0,8)(23,24)(1) ..
AD-LT2=D-SCH	(1,13)(1)(14,18)(0,4)(19,24)(1) ..
AD-LT3=D-SCH	(1,8)(1)(9,15)(0,4)(16,24)(1) ..
AD-LT4=D-SCH	(1,24)(0) ..
AD-LT=W-SCH	(MON,FRI) AD-LT1 (SAT) AD-LT2 (SUN)
	AD-LT3 (HOL) AD-LT4 ..
ADM-LT-SCH=SCH	THRU DEC 31 AD-LT ..
GYM-LT1=D-SCH	(1,8)(1)(9,13)(6,6,4,4,5)
	(14,15)(0)(16,18)(5,6,7)(19,24)(0) ..
GYM-LT2=D-SCH	(1,24)(0) ..
GYM-LT=W-SCH	(MON,FRI) GYM-LT1 (WEH) GYM-LT2 ..
GYM-LT-SCH=SCH	THRU DEC 31 GYM-LT ..
L/LT1=D-SCH	(1,24)(0) ..
L/LT2=D-SCH	(1,9)(0)(10,11)(7)(12,24)(0) ..
LT-SCH=W-SCH	(MON,SAT) L/LT1 (SUN,HOL) L/LT2 ..
L/SANCT-LT-SCH=SCH	THRU DEC 31 LT-SCH ..
C/LT1=D-SCH	(1,24)(0) ..
C/LT2=D-SCH	(1,17)(0)(18,19)(8)(20,24)(0) ..
C/LT3=D-SCH	(1,8)(0)(9,10)(8)(11,24)(0) ..
C/LT4=D-SCH	(1,6)(0)(7,8)(7)(9,24)(0) ..
C/LT5=D-SCH	(1,13)(0)(14,15)(8)

C/LT6=D-SCH	(16,24)(0) ..
C/LT=W-SCH	(1,8)(0)(9,13)(.6)(14,24)(0) ..
	(MON) C/LT1 (HOL) C/LT1
	(TUE) C/LT2 (WED) C/LT3
	(THU,FRI) C/LT4 (SAT) C/LT5 (SUN) C/LT6 ..
C/SANCT-LT-SCH=SCH	THRU DEC 31 C/LT ..
ED/CL-LT1=D-SCH	(1,8)(.1)(9,15)(.7)(16,24)(.1) ..
ED/CL-LT2=D-SCH	(1,8)(.1)(9,15)(.7)(16,24)(.1) ..
ED/CL-LT3=D-SCH	(1,24)(0) ..
ED/CL-LT=W-SCH	(MON,FRI) ED/CL-LT1 (SAT) ED/CL-LT2
	(SUN,HOL) ED/CL-LT3 ..
ED/CL-LT-SCH=SCH	THRU DEC 31 ED/CL-LT ..
SCHOOL-LT1=D-SCH	(1,6)(0)(7,10)(.8)(11,24)(0) ..
SCHOOL-LT2=D-SCH	(1,8)(0)(9,11)(.8)(12,24)(0) ..
SCHOOL-LT3=D-SCH	(1,24)(0) ..
SCHOOL-LT=W-SCH	(MON,FRI) SCHOOL-LT1
	(SUN) SCHOOL-LT2 (SAT) SCHOOL-LT3
	(HOL) SCHOOL-LT3 ..
SCHOOL-LT-SCH=SCH	THRU DEC 31 SCHOOL-LT ..
NUR-LT1=D-SCH	(1,8)(0)(9,13)(.8,.7,.7,.7,.7)
	(14,18)(0)(19,21)(.8,.7,.7)(22,24)(0) ..
NUR-LT2=D-SCH	(1,24)(0) ..
NUR-LT=W-SCH	(MON,FRI) NUR-LT1 (WEH) NUR-LT2 ..
NUR-LT-SCH=SCH	THRU DEC 31 NUR-LT ..

\$---EQUIPMENT SCHEDULE---\$

ADM-EQUIP1=D-SCH	(1,7)(0)(8,17)(.1,.3,.9,.5,.8,.8,.8,.9,.8,.5)
	(18,19)(0.2)(20,24)(0) ..
ADM-EQUIP2=D-SCH	(1,24) (0) ..
ADM-EQUIP=W-SCH	(MON,FRI) ADM-EQUIP1
	(WEH) ADM-EQUIP2 ..
ADM-EQUIP-SCH=SCH	THRU DEC 31 ADM-EQUIP ..

\$---INFILTRATION SCHEDULE---\$

INF-SCH=SCH THRU DEC 31 (ALL)(1,4)(1)(5,19)(0)(20,24)(1) ..

\$---INFILTRATION-VESTIBULE---\$

INF-VES1=D-SCH	(1,5)(0)(6,7)(0.08,0.02)(8,9)(.8,.6)(10,11)(.3)
	(12,14) (.5,.8,.5)(15,16) (.3)
	(17,18) (.4,.8)(19,24) (0) ..
INF-VES2=D-SCH	(1,12)(0)(13,14)(0.5)(15,24)(0) ..
INF-VES3=D-SCH	(1,9)(0)(10,13)(0.8)(14,24)(0) ..

INF-VES4=D-SCH (1,24)(0) ..
 INF-VES=W-SCH (MON,FRI) INF-VES1 (SAT) INF-VES2
 (SUN) INF-VES3 (HOL) INF-VES4 ..
 INF-VES-SCH=SCH THRU DEC 31 INF-VES ..

\$---SPACE CONDITIONS---

OFFICE = S-C

PEOPLE-HG-SCHEDULE=OFF-OCC-SCH
 PEOPLE-HG-LAT=190
 PEOPLE-HG-SENS=230
 NUMBER-OF-PEOPLE=10
 LIGHTING-SCHEDULE=OFF-LT-SCH
 LIGHTING-KW =0.08
 LIGHTING-TYPE=SUS-FLUOR
 INF-METHOD=AIR-CHANGE
 INF-CFM/SQFT=0.039
 INF-SCHEDULE=INF-SCH
 ZONE-TYPE=CONDITIONED
 FLOOR-WEIGHT=70

TEMPERATURE=(70)
 DAYLIGHTING=NO .. \$OFFICE IN MEZZANINE

ADMINIST=S-C

LIKE OFFICE
 NUMBER-OF-PEOPLE=6
 PEOPLE-SCHEDULE=ADM-OCC-SCH
 LIGHTING-SCHEDULE= ADM-LT-SCH
 LIGHTING-W/SQFT=1.4
 EQUIPMENT-W/SQFT=1.5
 EQUIP-SCHEDULE=ADM-EQUIP-SCH ..

\$ADMINISTRATION

GYM/HALL=S-C

LIKE OFFICE
 PEOPLE-HG-LAT=615
 PEOPLE-HG-SENS=345
 NUMBER-OF-PEOPLE=30
 PEOPLE-SCHEDULE=GYM-OCC-SCH
 LIGHTING-W/SQFT=1.4
 LIGHTING-TYPE=INCAND
 FLOOR-WEIGHT=30.0 ..

\$GYM/HALL

L/SANCT=S-C

LIKE OFFICE
 NUMBER-OF-PEOPLE=100
 PEOPLE-SCHEDULE= L/SANCT-OCC-SCH
 LIGHTING-KW=4.2
 LIGHTING-TYPE=INCAND
 LIGHTING-SCHEDULE=L/SANCT-LT-SCH ..

\$LUTHERAN SANCTUARY

C/SANCT=S-C	LIKE OFFICE NUMBER-OF-PEOPLE=125 PEOPLE-SCHEDULE= C/SANCT-OCC-SCH LIGHTING-KW=5.1 LIGHTING-TYPE=INCAND LIGHTING-SCHEDULE=C/SANCT-LT-SCH .. \$CATHOLIC SANSTUARY
CHAP=S-C	LIKE C/SANCT NUMBER-OF-PEOPLE=15 LIGHTING-W/SQFT=1.44 .. \$CHAPEL
CLROOM1=S-C	LIKE OFFICE NUMBER-OF-PEOPLE=20 PEOPLE-SCHEDULE= ED/CL-OCC-SCH LIGHTING-KW=0.7 LIGHTING-TYPE=SUS-FLUOR LIGHTING-SCHEDULE=ED/CL-LT-SCH .. \$MEZZANINE CLASSROOM1
CLROOM2=S-C	LIKE OFFICE NUMBER-OF-PEOPLE=20 PEOPLE-SCHEDULE=SCHOOL-OCC-SCH LIGHTING-KW=1.28 LIGHTING-TYPE=SUS-FLUOR LIGHTING-SCHEDULE= SCHOOL-LT-SCH .. \$MEZZANINE CLASSROOM2
NURSERY=S-C	LIKE OFFICE NUMBER-OF-PEOPLE=18 PEOPLE-SCHEDULE=NUR-OCC-SCH LIGHTING-W/SQFT=1.5 LIGHTING-SCHEDULE=NUR-LT-SCH LIGHTING-TYPE=SUS-FLUOR .. \$NURSERY
BCZ2-1=S-C	AREA/PERSON=150 PEOPLE-SCHEDULE=GYM-OCC-SCH LIGHTING-KW=1.36 LIGHTING-SCHEDULE=GYM-LT-SCH LIGHTING-TYPE=SUS-FLUOR DAYLIGHTING=NO Z-TYPE=CONDITIONED TEMPERATURE=(70) INF-CFM/SQFT=0.0 .. \$BASEMENT CORE ZONE2
BCZ4-1=S-C	LIKE BCZ2-1 AREA/PERSON=200 LIGHTING-KW=0.9 .. \$BASEMENTCORE (CORIDOR) ZONE
BVES1-1=S-C	TEMPERATURE=(72) ZONE-TYPE=CONDITIONED

LIGHTING-TYPE=SUS-FLUOR
 LIGHTING-KW=0.3
 INF-SCHEDULE= INF-VES-SCH
 INF-METHOD=AIR-CHANGE
 INF-CFM/SQFT=0.0 \$NO INFILTRATION
 AREA/PERSON=150
 DAYLIGHTING=NO .. \$BASEMENT VESTIBULE

MVES1=S-C LIKE BVES1-1
 LIGHTING-TYPE=INCAND
 LIGHTING-KW=0.45
 DAYLIGHTING=NO .. \$NO INFILTRATION
 \$MAIN FLOOR VESTIBULE 1

MVES2-1=S-C LIKE MVES1
 INF-METHOD=AIR-CHANGE
 INF-CFM/SQFT=1.6 .. \$MAIN FLOOR VESTIBULE 2

MSTR=S-C LIKE OFFICE
 LIGHTING-W/SQFT=1
 PEOPLE-SCHEDULE= ED/CL-OCC-SCH
 AREA/PERSON=150 .. \$MAIN FLOOR STAIRCASE

LOBBY=S-C LIKE ADMINIST
 TEMPERATURE=(70)
 LIGHTING-W/SQFT=1.3
 LIGHTING-TYPE=INCAND
 AREA/PERSON=250
 EQUIPMENT-W/SQFT=0 .. \$MAIN LOBBY

MEZCZ1=S-C AREA/PERSON=250
 LIGHTING-KW=2.55
 LIGHTING-SCHEDULE= ED/CL-OCC-SCH
 LIGHTING-TYPE=INCAND
 DAYLIGHTING=NO
 Z-TYPE=CONDITIONED
 TEMPERATURE=(70)
 INF-CFM/SQFT=0.0 .. \$MEZZANINE CORE ZONE1

MECHANICAL=S-C Z-TYPE=UNCONDITIONED
 LIGHTING-W/SQFT=1
 LIGHTING-TYPE=INCAND
 INF-METHOD=AIR-CHANGE
 INF-CFM/SQFT=0.02
 DAYLIGHTING=NO .. \$MECHANICAL PLUS MEZ. STORE

PLAYROOM=S-C Z-TYPE=CONDITIONED
 TEMPERATURE=(70)

NUMBER-OF-PEOPLE=20
 PEOPLE-SCHEDULE= SCHOOL-OCC-SCH
 LIGHTING-SCHEDULE =SCHOOL-LT-SCH
 LIGHTING-W/SQFT=1.5
 LIGHTING-TYPE=SUS-FLUOR
 FLOOR-WEIGHT=30.0
 INF-SCHEDULE= INF-SCH
 INF-CFM/SQFT=0.039
 DAYLIGHTING=NO ..
 \$MEZZANINE FLOOR PLAYROOM
 RECCENTER=S-C LIKE NURSERY
 NUMBER-OF-PEOPLE=17
 PEOPLE-SCHEDULE=SCHOOL-OCC-SCH
 LIGHTING-W/SQFT=1.5
 LIGHTING-SCHEDULE=SCHOOL-LT-SCH
 LIGHTING-TYPE=SUS-FLUOR
 INF-SCHEDULE=INF-SCH ..

\$----SPACEFIC SPACE DETAIL-----\$
 \$----BASEMENT-----\$
 \$--BASEMENT FL ZONE1---\$

BZ1=SPACE SPACE-CONDITIONS=GYM/HALL
 AREA=3845 VOLUME=95873 ..
 BZ1FL=U-F CONS=FLOOR-TYPE1
 AREA=3845 ..
 BZ1WUNG1=U-W CONS=WALL3
 AZ=180 HEIGHT=8.2 WIDTH=22 ..
 BZIW1=E-W CONS=WALL1
 AZ=180 HEIGHT=11.5 WIDTH=26 ..
 BZ1WIN1=WI G-T=GL-TYPE1
 HEIGHT=4.92 WIDTH=6.56 ..
 BZ1WUNG2=U-W CONS=WALL3
 AZ=-90 HEIGHT=8.2 WIDTH=80.7 ..
 BZIW2=E-W CONS=WALL1
 AZ=-90 HEIGHT=11.5 WIDTH=62 ..
 BZ1WIN2=WI LIKE BZ1WIN1 ..
 BZIWUNG3= U-W CONS=WALL3
 AZ= 0 HEIGHT=8.2 WIDTH=52 ..
 BZIW3=E-W CONS=WALL1
 AZ= 0 HEIGHT=11.5 WIDTH=55.77 ..
 BZ1WIN3=WI LIKE BZ1WIN1 ..
 BZ1IW1=I-W CONS=WALL7

BZ1IW2=I-W NEXT-TO BZ2 AREA=2403 ..
 CONS=WALL8
 BZ1RF=ROOF NEXT-TO BZ4 AREA=668 ..
 CONS=ROOF1
 HEIGHT=50.5 WIDTH=80.7 TILT=15 ..

\$--BASEMENT FL ZONE2 ---\$

BZ2=SPACE S-C=BCZ2-1 VOLUME=18249 AREA=1918 ..
 BZ2FL=U-F CONS=FLOOR-TYPE1
 AREA=1918 ..
 BZ2WUNG2=U-W CONS=WALL3
 HEIGHT=4.75 WIDTH=14 ..
 BZ2W1=E-W CONS=WALL10
 HEIGHT=4.6 WIDTH=14 AZ=0 ..
 BZ2IW1=I-W LIKE BZ1IW1 NEXT-TO BZ3 AREA=1027 ..
 BZ2IW2=I-W CONS=WALL5 NEXT-TO BZ4 AREA=225.74 ..
 BZ2IW3=I-W AREA=1918 NEXT-TO MZ1
 CONS=WALL5 TILT=0 .. \$ CEILING

\$--BASEMENT FL ZONE 3---\$

\$--REC CENTER---\$

BZ3=SPACE S-C=RECCENTER
 AREA=1836 VOLUME=16952 ..
 BZ3FL1= U-F CONS=FLOOR-TYPE1 AREA=1836 ..
 BZ3WUNG1=U-W CONS=WALL3
 AZ=0 HEIGHT=4.75 WIDTH=30.7 ..
 BZ3W1=E-W CONS=WALL10
 AZ=0 HEIGHT=4.6 WIDTH=30.7 ..
 BZ3WUNG2=U-W CONS=WALL3
 AZ=90 HEIGHT=4.75 WIDTH=62.14 ..
 BZ3W2=E-W CONS=WALL10
 AZ=90 HEIGHT=4.9 WIDTH=62.14 ..
 BZ3WIN1=WI G-T=GL-TYPE1
 HEIGHT=4.6 WIDTH=16.4 ..
 BZ3WUNG3=U-W CONS=WALL3
 AZ=135 HEIGHT=4.75 WIDTH=13.12 ..
 BZ3W3=E-W CONS=WALL10
 AZ=135 HEIGHT=4.6 WIDTH=13.12 ..
 BZ3WIN2=WI G-T=GL-TYPE1
 HEIGHT=4.6 WIDTH=9.84 ..
 BZ3W4=E-W CONS=WALL10
 AZ=180 HEIGHT=9.35 WIDTH=9.84 ..
 BZ3IW1=I-W AREA=12.8 NEXT-TO BZ4
 CONS=WALL5 ..
 BZ3IW2=I-W AREA=1968.6 NEXT-TO MZ2
 TILT=0 CONS=WALL5 .. \$CEILING

\$--BASEMENT FL ZONE4--\$

\$--BASEMENT CORIDOR--\$

BZ4=SPACE	S-C= BCZ4-1
	AREA=585 VOLUME=2048 ..
BZ4FL1= U-F	CONS=FLOOR-TYPE1
	AREA=585 ..
BZ4WUNG1=U-W	CONS=WALL3 AREA=632.25 ..
BZ4IW1=I-W	CONS=WALL8 AREA=60.3 NEXT-TO BZ2 ..
BZ4IW2=I-W	CONS=WALL6 NEXT-TO BZ2 AREA=45.2 ..
BZ4IW3=I-W	CONS=WALL5 AREA=585 NEXT-TO MZ6

TILT=0 ..

\$CEILING

\$--BASEMENT VESTIBULE--\$

BVES1=SPACE	S-C=BVES1-1
	AREA=97 VOLUME=271.6
	DAYLIGHTING=NO ..
BVESW1=E-W	CONS=WALL1 HEIGHT=9.8 WIDTH=13 ..
BVESD1=DOOR	CONS=DR HEIGHT=7 WIDTH=5.9 ..
BVESFL1= U-F	CONS=FLOOR-TYPE1 AREA=97 ..
BVESWUNG1=U-W	CONS=WALL3
	HEIGHT=9.8 WIDTH=7.5 ..
BVESC=I-W	CONS=WALL5
	NEXT-TO MZ3 TILT=0 AREA=97 ..

\$CEILING

\$---MAIN FLOOR ZONE1---\$

\$---NURSERY ---\$

MZ1=SPACE	S-C=NURSERY
	AREA=1372 VOLUME=10803 ..
MZ1C1=I-W	CONS=FLOOR-TYPE2
	NEXT-TO MEZZ1 AREA=1699.6 TILT=0 ..
	\$CEILING
MZ1W1=E-W	CONS=WALL1
	AZ= 0 HEIGHT=7.87 WIDTH=22 ..
MZ1WIN1=WI	G-T=GL-TYPE1 HEIGHT=4.92 WIDTH=6.56 ..
MZ1D1=DOOR	CONS=DR HEIGHT=7 WIDTH=5.9 ..
MZ1IW1=I-W	CONS=WALL7 NEXT-TO MZ2 AREA=468 ..
MZ1IW2=I-W	CONS=WALL6 NEXT-TO MZ6 AREA=51.7 ..
MZ1IW3=I-W	CONS=WALL5 AREA=573 NEXT-TO BZ1 ..

\$---MAIN FL ZONE 2---\$

\$---ADMINISTRATION---\$

MZ2=SPACE	S-C=ADMINIST AREA=2121 VOLUME=26791 ..
-----------	--

MZ2W1=E-W	CONS=WALL1	
	HEIGHT=9.18 WIDTH=31.17 AZ=0 ..	
MZ2WIN1=WI	G-T=GL-TYPE1	HEIGHT=4.92 WIDTH=9.84 ..
MZ2W2=E-W	CONS=WALL1	HEIGHT=9.18 WIDTH=63.65
		AZ=90 ..
MZ2WIN2=WI	G-T=GL-TYPE1	
	HEIGHT=4.92	WIDTH=26.24 ..
MZ2IW3=I-W	CONS=WALL7	NEXT-TO MZ3
	AREA=258.33 ..	
MZ2IW4=I-W	CONS=WALL7	
	NEXT-TO MZ6	AREA=90.4 ..
MZ1RF=ROOF	CONS=ROOF1	
	HEIGHT=25	WIDTH=80.7 TILT=15 ..
\$---MAIN FL ZONE3---\$		
\$---CHAPEL---\$		
MZ3=SPACE	S-C=CHAP	AREA=371.7 VOLUME=4878 ..
MZ3W1=E-W	CONS=WALL1	
	AZ=90	HEIGHT=13.12 WIDTH=13.12 ..
MZ3WIN1=WI	LIKE BZ1WIN1	HEIGHT=6.56 WIDTH=6.56 ..
MZ3IW1=I-W	CONS=WALL7	AREA=323 NEXT-TO MZ4 ..
MZ3IW2=I-W	CONS=WALL7	AREA=161.5 NEXT-TO MZ6 ..
MZ3RF=ROOF	CONS=ROOF1	
	HEIGHT=25	WIDTH=13.12 TILT=15 ..
MZ3FL1=U-F	CONS=FLOOR-TYPE2	AREA=371.7 ..
\$---MAIN FL ZONE4---\$		
\$---C/SANCTURY---\$		
MZ4=SPACE	S-C= C/SANCT	AREA=4345 VOLUME=74654 ..
MZ4FL1= U-F	CONS=FLOOR-TYPE1	AREA=4345 ..
MZ4RF=ROOF	CONS=ROOF3	HEIGHT=60 WIDTH=52
		TILT=15 ..
MZ4W1=E-W	CONS=WALL2	AZ=0 HEIGHT=2 WIDTH=25 ..
MZ4W2=E-W	CONS=WALL1	AZ=0 HEIGHT=17.3 WIDTH=25 ..
MZ4WIN1=WI	LIKE BZ1WIN1	WIDTH=6.56 ..
MZ4W3=E-W	CONS=WALL2	AZ=45 HEIGHT=2 WIDTH=13 ..
MZ4W4=E-W	CONS=WALL1	AZ=45 HEIGHT=12.5 WIDTH=13 ..
MZ4WIN2=WI	LIKE BZ1WIN1	..
MZ4W5=E-W	CONS=WALL2	AZ=90 HEIGHT=2 WIDTH=4 ..
MZ4W6=E-W	CONS=WALL1	HEIGHT=12 WIDTH=4 AZ=90 ..
MZ4W7=E-W	CONS=WALL2	AZ=45 HEIGHT=2 WIDTH=21 ..
MZ4W8=E-W	CONS=WALL1	AZ=45 HEIGHT=10 WIDTH=21 ..
MZ4W9=E-W	CONS=WALL2	HEIGHT=2 WIDTH=8.2 AZ=90 ..
MZ4W10=E-W	CONS=WALL1	HEIGHT=6.5 WIDTH=8.2 AZ=90 ..
MZ4WIN3=WI	LIKE BZ1WIN1	HEIGHT=3.28 WIDTH=6.56 ..

MZ4W11=E-W	CONS=WALL2	AZ=135 HEIGHT=2 WIDTH=21 ..
MZ4W12=E-W	CONS=WALL1	AZ=135 HEIGHT=8.5 WIDTH=21 ..
MZ4W13=E-W	CONS=WALL2	AZ=90 HEIGHT=14 WIDTH=4 ..
MZ4W14=E-W	CONS=WALL2	AZ=135 HEIGHT=2 WIDTH=13 ..
MZ4W15=E-W	CONS=WALL1	AZ=135 HEIGHT=12.5
	WIDTH=13 ..	
MZ4WIN4=WI	LIKE BZ1WIN1	..
MZ4W16=E-W	CONS=WALL2	AZ=180 HEIGHT=2
		WIDTH=15.7 ..
MZ4W17=E-W	CONS=WALL1	AZ=135 HEIGHT=13.7 WIDTH=21 ..
MZ4W18=E-W	CONS=WALL2	AZ=90 HEIGHT=2 WIDTH=7.54 ..
MZ4W19=E-W	CONS=WALL1	AZ=135 HEIGHT=8 WIDTH=21 ..
MZ4W20=E-W	CONS=WALL1	AZ=180 HEIGHT=13.5
		WIDTH=21 ..
MZ4WIN5=WI	LIKE BZ1WIN1	HEIGHT=5.9 WIDTH=19.7 ..
MZ4W26=E-W	CONS=WALL1	HEIGHT=8 WIDTH=20 AZ=180 ..
MZ4RF1=ROOF	CONS=ROOF3	HEIGHT=19 WIDTH=6.5
	TILT=15 ..	
MZ4IW1=I-W	CONS=WALL7	AREA=500.5 NEXT-TO MZ6 ..
MZ4IW2=I-W	CONS=WALL5	AREA=368 NEXT-TO MZ6 ..
MZ4W21=E-W	CONS=WALL1	AZ=0 HEIGHT=2.3 WIDTH=14 ..
MZ4WIN6=WI	LIKE BZ1WIN1	HEIGHT=1.8 WIDTH=6.6 ..
MZ4W22=E-W	CONS=WALL1	AZ=90 HEIGHT=8.2
		WIDTH=10.5 ..
MZ4WIN7=WI	LIKE BZ1WIN1	HEIGHT=5.8 WIDTH=5.8 ..
MZ4W23=E-W	CONS=WALL1	AZ=45 HEIGHT=6 WIDTH=8.8 ..
MZ4WIN8=WI	LIKE BZ1WIN1	HEIGHT=4 WIDTH=5.8 ..
MZ4W24=E-W	CONS=WALL1	AZ=180 HEIGHT=2.3
		WIDTH=14 ..
MZ4WIN9=WI	LIKE BZ1WIN1	HEIGHT=1.8 WIDTH=6.6 ..
MZ4W25=E-W	CONS=WALL1	AZ=135 HEIGHT=6 WIDTH=8.8 ..
MZ4WIN10=WI	LIKE BZ1WIN1	HEIGHT=4 WIDTH=5.8 ..
 \$--MAIN FL VESTIBULE--\$		
MVES=SPACE	S-C= MVES2-1	AREA=201.8 VOLUME=1986.4
	DAYLIGHTING=NO	..
MVESW1=E-W	CONS=WALL1	AZ=180 HEIGHT=9.8 WIDTH=24.6 ..
MVESWIN1=WI	LIKE BZ1WIN1	HEIGHT=4.9 WIDTH=6.6 ..
MVESD1=WI	G-T=DRGL-TYPE3	HEIGHT=6.9 WIDTH=11.8 ..
MVESW2=E-W	CONS=WALL1	AZ=90 HEIGHT=9.84 WIDTH=9.84 ..
MVESIW1=I-W	CONS=WALL5	AREA=96.9 NEXT-TO MFLSTR ..
MVESIW2=I-W	CONS=WALL7	AREA=145.4 NEXT-TO MZ5 ..
MVESD2=I-W	CONS=WALL5	AREA=81 NEXT-TO MZ5 ..

MVESCL=I-W CONS=WALL5 NEXT-TO MEZZ1 TILT=0
 AREA=201.82 ..

\$CEILING
 MVESFL1= U-F CONS=FLOOR-TYPE1 AREA=201.82 ..

\$---MAIN FL STAIRCASE ZONE---\$

MFLSTR=SPACE	S-C= MSTR	AREA=113 VOLUME=2907 ..
MFLSTRW1=E-W	CONS=WALL1	AZ= 180 HEIGHT=23.4 WIDTH=14
..		
MFLSTRD1=DOOR	CONS= DR	HEIGHT=3.28 WIDTH=9.18 ..
MFLSTRWIN1=WI	LIKE BZ1WIN1	HEIGHT=4.9 WIDTH=6.6 ..
MFLSTRW2=E-W	CONS=WALL1	AZ= 90 HEIGHT=21.33 WIDTH=9.84
..		
MFLSTRWIN2=WI	LIKE BZ1WIN1	HEIGHT=4.26 WIDTH=6.56 ..
MFLSTRIW1=I-W	CONS=WALL7	AREA=210 NEXT-TO MVES ..
MFLSTRIW2=I-W	CONS=WALL7	AREA=324 NEXT-TO MZ5 ..
MFLSTRFL= U-F	CONS=FLOOR-TYPE1	AREA=113 ..
MFLSTRRF=ROOF	CONS=ROOF1	HEIGHT=13 WIDTH=9.84
	TILT=15 ..	

\$---MAIN FL ZONE5---\$

\$-L/SANCTURY---\$

MZ5=SPACE	S-C= L/SANCT	AREA=2906 VOLUME=51449 ..
MZ5FL1= U-F	CONS=FLOOR-TYPE1	AREA=2906 ..
MZ5W1=E-W	CONS=WALL2	AZ=0 HEIGHT=2 WIDTH=24 ..
MZ5W2=E-W	CONS=WALL1	AZ=0 HEIGHT=17 WIDTH=24 ..
MZ5D1=DOOR	CONS=DR	HEIGHT=7 WIDTH=5.9 ..
MZ5W3=E-W	CONS=WALL2	AZ=-90 HEIGHT=2 WIDTH=13 ..
MZ5W4=E-W	CONS=WALL1	AZ=-45 HEIGHT=12.5 WIDTH=24 ..
MZ5WIN2=WI	LIKE BZ1WIN1	..
MZ5W5=E-W	CONS=WALL2	AZ=-90 HEIGHT=2 WIDTH=4 ..
MZ5W6=E-W	CONS=WALL1	AZ=-90 HEIGHT=12 WIDTH=4 ..
MZ5W7=E-W	CONS=WALL1	AZ=-45 HEIGHT=10.5 WIDTH=21 ..
MZ5W8=E-W	CONS=WALL1	HEIGHT=8.5 WIDTH=8.2 AZ=-90 ..
MZ5WIN3=WI	LIKE BZ1WIN1	HEIGHT=3.28 WIDTH=6.56 ..
MZ5W9=E-W	CONS=WALL1	AZ=-135 HEIGHT=10.5 WIDTH=21.3 ..
MZ5W10=E-W	CONS=WALL2	AZ=-90 HEIGHT=2 WIDTH=4 ..
MZ5W11=E-W	CONS=WALL1	AZ=-90 HEIGHT=12 WIDTH=4 ..
MZ5W12=E-W	CONS=WALL2	AZ=-135 HEIGHT=2 WIDTH=13 ..
MZ5W13=E-W	CONS=WALL1	AZ=-135 HEIGHT=12.5 WIDTH=13 ..
MZ5WIN4=WI	LIKE BZ1WIN1	..
MZ5W14=E-W	CONS=WALL2	AZ=-180 HEIGHT=2 WIDTH=15 ..
MZ5W15=E-W	CONS=WALL1	AZ=-180 HEIGHT=13.7 WIDTH=15 ..
MZ5W16=E-W	CONS=WALL2	AZ=-90 HEIGHT=2 WIDTH=7.5 ..
MZ5W17=E-W	CONS=WALL2	AZ=-90 HEIGHT=8 WIDTH=7.5 ..

MEZZ1=SPACE	S-C=OFFICE AREA=165 VOLUME=1621 ..
MEZZ1W1=E-W	CONS=WALL1 AZ=180 HEIGHT=9.84 WIDTH=14.43 ..
MEZZ1W2=E-W	CONS=WALL1 AZ=-90 HEIGHT=9.84 WIDTH=11.15 ..
MEZZ1WIN1=WI	LIKE BZ1WIN1 HEIGHT=4.26 WIDTH=6.56 ..
MEZZ1IW1=I-W	CONS=WALL5 AREA=371.4 NEXT-TO MEZSTR ..
MEZZ1IW2=I-W	CONS=WALL5 AREA=165 NEXT-TO MEZP1
	TILT=0 ..

\$---UNCONDITIONED SPACE OF MEZZANINE ZONE1

MEZZP1=SPACE	Z-T=PLENUM AREA=165 VOLUME=429
	FLOOR-WEIGHT=5 ..
MEZZP1W1=E-W	CONS=WALL1 HEIGHT=2.46 WIDTH=14.46
	AZ=-90 ..
MEZZP1IW=I-W	CONS=WALL5 AREA=48.43 NEXT-TO MEZCZ ..
MEZZP1RF=ROOF	CONS=ROOF1 HEIGHT=15 WIDTH=11
	TILT=15 ..

\$---MEZZANINE CORE ZONE---\$

MEZCZ=SPACE	S-C= MEZCZ1	AREA=1880.8 VOLUME=29568 ..
MEZCZIW1=I-W	CONS=WALL5	AREA=516.7 NEXT-TO MEZCL1 ..
MEZCZIW2=I-W	CONS=WALL5	AREA=516.7 NEXT-TO MEZCL2 ..
MEZCZIW3=I-W	CONS=WALL5	AREA=403 NEXT-TO MEZSTR ..
MEZCW1=E-W	CONS=WALL1	HEIGHT=14.76 WIDTH=21.3
	AZ= 90 ..	
MEZCWIN1=WI	G-T=GL-TYPE2	HEIGHT=4.92 WIDTH=19.68 ..
MEZCW2=E-W	CONS=WALL1	HEIGHT=14.76 WIDTH=21.3
	AZ=-90 ..	
MEZCWIN2=WI	G-T=GL-TYPE2	HEIGHT=4.92 WIDTH=19.68 ..
MEZCW3=E-W	CONS=WALL1	HEIGHT=10.7 WIDTH=26.3
	AZ= 0 ..	
MEZCW4=E-W	CONS=WALL1	HEIGHT=13 WIDTH=26.3
	AZ=180 ..	
MEZCWIN3=WI	G-T=GL-TYPE1	HEIGHT=3.3 WIDTH=23 ..
MEZCW5=E-W	CONS=WALL1	HEIGHT=9 WIDTH=43 AZ=0 ..
MEZCWIN4=WI	G-T=GL-TYPE1	HEIGHT=4 WIDTH=4.75 ..
MEZCRF1=ROOF	CONS=ROOF1	HEIGHT=20 WIDTH=24.6
	TILT=15 ..	

\$--MEZZANINE CLASS ROOM1 AT THE TOP OF THE C/SANCTURY---\$

MEZCL1=SPACE	S-C=CLROOM1	AREA=927.85 VOLUME=9132.3 ..
MEZCL1W1=E-W	CONS=WALL1	HEIGHT=9 WIDTH=10 AZ=180 ..
MEZCL1WIN3=WI	G-T=GL-TYPE1	HEIGHT=4 WIDTH=4.75 ..
MEZCL1W3=E-W	CONS=WALL1	HEIGHT=9 WIDTH=27.5AZ=0 ..
MEZCL1WIN4=WI	G-T=GL-TYPE1	HEIGHT=4 WIDTH=4.75 ..
MEZCL1IW1=I-W	CONS=WALL5	AREA=791 NEXT-TO MZ4 ..
MEZCL1IW2=I-W	CONS=WALL5	AREA=742.7 NEXT-TO MEZCZ ..
MEZCL1FL=I-W	CONS=WALL5	AREA=927.85 NEXT-TO MZ6 ..
MEZCL1C=I-W	CONS=WALL5	AREA=927.85 NEXT-TO MEZCL1P

TILT=0 .. \$CEILING

\$---UNCONDITIONED SPACE OF MEZZANINE CLASS ROOM1

MEZCL1P=SPACE ZONE-TYPE=PLENUM AREA=927.85 VOLUME=329
 FLOOR-WEIGHT=5 ..

MEZCL1RF=ROOF CONS=ROOF1 HEIGHT=12.8 WIDTH=69.55
 TILT=15 ..

\$--MEZZANINE CLASS ROOM2 AT THE TOP OF THE L/SANCTURY--\$

MEZCL2=SPACE S-C=CLROOM2 AREA=1266 VOLUME=12460 ..
 MEZCL2W1=E-W CONS=WALL1 HEIGHT=9 WIDTH=15.7
 AZ=180 ..

MEZCL2WIN1=WI G-T=GL-TYPE1 HEIGHT=4.75 WIDTH=4 ..
 MEZCL2IW1=I-W CONS=WALL5 AREA=791 NEXT-TO MZ5 ..
 MEZCL2IW2=I-W CONS=WALL5 AREA=742.7 NEXT-TO MEZCZ ..
 MEZCL2W2=E-W CONS=WALL1 HEIGHT=9 WIDTH=26 AZ=0 ..
 MEZCL2WIN2=WI G-T=GL-TYPE1 HEIGHT=4.75 WIDTH=4 ..
 MEZCL2FL=I-W CONS=WALL5 AREA=927.85 NEXT-TO MZ4 ..
 MEZCL2C=I-W CONS=WALL5 AREA=1266 NEXT-TO MEZCL2P
 TILT=0 ..

\$CEILING

\$----UNCONDITIONED SPACE OF MEZZANINE CLASS ROOM2

MEZCL2P=SPACE ZONE-TYPE=PLENUM AREA=1266
 VOLUME=3115 FLOOR-WEIGHT=5 ..

MEZCL2RF=ROOF CONS=ROOF1 HEIGHT=17 WIDTH=69.55
 TILT=15 ..

\$--MENZANINE STAIRCASE----\$

MEZSTR=SPACE S-C= MSTR AREA=667 VOLUME=12011 ..
 MEZSTRW1=E-W CONS=WALL1 HEIGHT=13 WIDTH=26 AZ= 0 ..
 MEZSTRIW1=I-W CONS=WALL5 AREA=700 NEXT-TO MEZCL2 ..
 MEZSTRIW2=I-W CONS=WALL5 AREA=646 NEXT-TO MEZCZ ..
 MEZSTRW3=E-W CONS=WALL1 HEIGHT=21 WIDTH=18 AZ=90 ..
 MEZSTRWIN=WI G-T=GL-TYPE1 HEIGHT=3.3 WIDTH=6.6 ..
 MEZSTRFL=U-F CONS=FLOOR-TYPE1 AREA=667 ..
 MFLSTRRF1=ROOF CONS=ROOF1 HEIGHT=42.65 WIDTH=39.37
 TILT=15 ..

\$---MECHANICAL ROOM---\$

\$--ZONE WHICH IS NOT CONDITIONED---\$

MECRM=SPACE S-C= MECHANICAL AREA=2258 VOLUME=22224.4 ..
 MECIW1=I-W CONS=WALL5 AREA=888 NEXT-TO BZ1 ..
 MECIW2=I-W CONS=WALL5 AREA=290 NEXT-TO PLRM ..
 MECIW3=I-W CONS=WALL5 AREA=409 NEXT-TO BZ3 ..
 MECIW4=I-W CONS=FLOOR-TYPE2

MECRF1=ROOF AREA=2258 NEXT-TO BZ2 TILT=0 ..
 CONS=ROOF1 HEIGHT=29 WIDTH=63
 TILT=15 ..
 MECRF2=ROOF CONS=ROOF2 HEIGHT=9.5 WIDTH=16
 TILT=0 ..
\$---PALY ROOM ---\$

 PLRM=SPACE S-C=PLAYROOM AREA=503 VOLUME=4951 ..
 PLRMW1=E-W CONS=WALL1 HEIGHT=11 WIDTH=19 AZ=0 ..
 PLRMWIN1=W G-T=GL-TYPE1 HEIGHT=4.6 WIDTH=6.5 ..
 PLRMIW1=I-W CONS=WALL5 AREA=320 NEXT-TO MEZFLST ..
 PLRMFL=I-W CONS=WALL5 AREA=503 NEXT-TO MZ1 ..
 PLRMRF=ROOF CONS=ROOF1 HEIGHT=17.7 WIDTH=28
 TILT=15 ..

\$---MEZZANINE FL STAIRCASE ZONE---\$

 MEZFLST=SPACE S-C=MSTR AREA=188 VOLUME=5563 ..
 MEZFLSTW1=E-W CONS=WALL1 AZ= 0 HEIGHT=8.2 WIDTH=12.5 ..
 MEZFLSTIW1=I-W CONS=WALL7 AREA=183 NEXT-TO MZ2 ..
 MEZFLSTIW2=I-W CONS=WALL7 AREA=66 NEXT-TO MECRM ..
 MEZFLSTRF=ROOF CONS=ROOF1 HEIGHT=11 WIDTH=14.7
 TILT=15 ..

 END ..
 COMPUTE LOADS ..

 INPUT SYSTEMS ..

\$----HVAC SYSTEMS SCHEDULES FOR AHU-1

 FAN-ON1=SCH THRU DEC 31 (ALL)(1,4)(0) (5,19)(1) (20,24)(0) ..

\$--- HVAC SYSTEMS SCHEDULES FOR AHU-2

 FAN-ON2=SCH THRU DEC 31 (ALL)(1,4)(0) (5,19)(1) (20,24)(0) ..

\$---- HVAC SYSTEMS SCHEDULES FOR AHU-3

 FAN-ON3=SCH THRU DEC 31 (MON,FRI)(1,7)(0) (8,21)(1) (22,24)(0)
 (WEH)(1,24)(0) ..
 HEATSETPT1=SCH THRU DEC 31 (ALL)(1,5)(61)(6,19)(70) (20,24)(61) ..
 HEATSETPT2=SCH THRU DEC 31 (ALL)(1,5)(61)(6,19)(68) (20,24)(61) ..
 HEATSETPT3=SCH THRU DEC 31 (MON,FRI)(1,7)(61) (8,22)(68)
 (23,24)(60)(WEH)(1,24)(61) ..
\$BASEBOARD RESET SCHEDULE

DRS1=DAY-RESET-SCH SUPPLY-HI=1 SUPPLY-LO=0 OUTSIDE-HI=68
 OUTSIDE-LO=0 ..
 DRS= RESET-SCH THRU DEC 31 (ALL) DRS1 ..

COOL-OFF=SCH THRU DEC 31 (ALL)(1,24)(0) ..

HEATON=SCH THRU MAY 15 (ALL)(1,24)(1)
 THRU AUG 31 (ALL)(1,24)(0)
 THRU DEC 31 (ALL)(1,24)(1) ..

SUMMER-VENT=SCH THRU MAY 31 (ALL)(1,24)(0)
 THRU OCT 31 (ALL)(1,24)(1)
 THRU DEC 31 (ALL)(1,24)(0) ..

VENT-SETPT=SCH THRU DEC 31 (ALL)(1,24)(74) ..

\$ZONE SUB-COMMANDS

ZCON1=Z-C DESIGN-HEAT-T=68
 HEAT-TEMP-SCH=HEATSETPT1
 BASEBOARD-CTRL=THERMOSTATIC
 THERMOSTAT-TYPE=PROPORTIONAL
 THROTTLING-RANGE=4 ..

ZCON2=Z-C DESIGN-HEAT-T=68
 HEAT-TEMP-SCH=HEATSETPT2
 B-C=THERMOSTATIC
 THERMOSTAT-TYPE=PROPORTIONAL
 THROTTLING-RANGE=4 ..

ZCON3=Z-C DESIGN-HEAT-T=68
 HEAT-TEMP-SCH=HEATSETPT3
 B-C=THERMOSTATIC
 THERMOSTAT-TYPE=PROPORTIONAL
 THROTTLING-RANGE=4 .. \$GYM/HALL

ZAIR1=Z-A OA-CFM/PER=10
 AIR-CHANGES/HR=4 ..

ZAIR2=Z-A OA-CFM/PER=15
 AIR-CHANGES/HR=4 ..

ZAIR3=Z-A OA-CFM/PER=10
 AIR-CHANGES/HR=4 ..

\$--SYSTEM DESCRIPTION

\$--GYM/HALL; AHU-3

BZ1=ZONE Z-T=CONDITIONED
 Z-C=ZCON3
 Z-A=ZAIR3

BASEBOARD-RATING=5120 .. \$BTU/HR

\$--SERVICE ZONES; AHU-2

BZ2=ZONE Z-T=CONDITIONED
 Z-C=ZCON2
 Z-A=ZAIR2
 ASSIGNED-CFM=106
 BASEBOARD-RATING=512 .. \$BASEMENT CORE ZONE
 BZ3=ZONE LIKE BZ2 ASSIGNED-CFM=1430
 EXHAUST-CFM=450 B-R=-2816 .. \$REC CENTER
 BZ4=ZONE LIKE BZ3 ASSIGNED-CFM=318 EXHAUST-CFM=225
 B-R=0 .. \$BASEMENT CORRIDOR
 MZ1=ZONE LIKE BZ4 ASSIGNED-CFM=954 EXHAUST-CFM=225
 MZ2=ZONE B-R=-1280 .. \$NUR/CORE ZONE
 LIKE MZ ASSIGNED-CFM=1059 EXHAUST-CFM=450
 B-R=-24403 .. \$ADMINISTRATION
 MZ3=ZONE LIKE MZ2 ASSIGNED-CFM=424 EXHAUST-CFM=150
 PLRM=ZONE B-R=-1024 .. \$CHAPEL
 LIKE MZ3 ASSIGNED-CFM=424 EXHAUST-CFM=100
 B-R=-1024 .. \$PLAYROOM IN MANZZANINE FL

\$--SANCTURIES, LOBBY, CLASS ROOMS AND OTHER AREA; AHU-1

MZ4=ZONE Z-T=CONDITIONED
 Z-C=ZCON1
 Z-A=ZAIR1
 ASSIGNED-CFM=3952
 EXHAUST-CFM=64
 BASEBOARD-RATING=-7781 ..
 \$C/SANCTUARY
 MZ5=ZONE LIKE MZ4 ASSIGNED-CFM=2702 EXHAUST-CFM=0
 B-R=-81912 .. \$L/SANCTUARY
 MZ6=ZONE LIKE MZ5 ASSIGNED-CFM=2236 B-R=-41843 ..
 \$LOBBY
 MEZZ1=ZONE LIKE MZ5 ASSIGNED-CFM=170 B-R=-512 ..
 \$MENZZANINE OFFICE
 MEZZP1=ZONE Z-T=PLENUM .. \$MEZZANINE OFFICE PLENUM
 MEZCZ=ZONE LIKE MEZZ1 ASSIGNED-CFM=848 B-R=-179 ..
 \$SPACE ABOVE THE LOBBY
 MEZCL1=ZONE LIKE MEZZ1 ASSIGNED-CFM=477 B-R=-2389 ..

MEZCL1P=ZONE LIKE MEZZP1 .. \$CLASSROOM ABOVE C/SANCT
 MEZCL2=ZONE LIKE MEZCL1 ASSIGNED-CFM=477 .. \$CLASSROOM1 PLENUM

MEZCL2P=ZONE LIKE MEZCL1P .. \$CLASSROOM ABOVE L/SANCT

MECRM=ZONE Z-T=UNCONDITIONED .. \$CLASSROOM2 PLENUM

\$MECHANICAL ROOM

\$UNIT HEATER SYSTEMS DESCRIPTION

FAN-ON4=SCH THRU DEC 31 (MON,FRI)(1,7)(0) (8,19)(.8) (20,24)(0)
 (SAT)(1,13)(0) (14,18)(.5) (19,24)(0)
 (SUN)(1,8)(0) (9,15)(.5) (16,24)(0)
 (HOL) (1,24)(0) ..
 HEATSETPT4=SCH THRU DEC 31 (MON,FRI)(1,7)(55)(8,19)(72) (20,24)(0)
 (SAT)(1,7)(55) (8,19)(70)(20,24)(55)
 (SUN)(1,8)(55)(9,19)(70)(20,24)(55)
 (HOL)(1,24)(55) ..

BVES1=ZONE Z-T=CONDITIONED
 DESIGN-HEAT-T=72
 HEAT-TEMP-SCH=HEATSETPT4
 H-CAP= -5802 .. \$BASEMENT VESTIBULE
 MVES=ZONE LIKE BVES1 H-CAP= -18430 .. \$MAIN FLOOR VESTIBULE 1
 MFLSTR=ZONE LIKE MVES H-CAP= -5802 .. \$MAIN FLOOR STAIRCASE
 MVES2=ZONE LIKE MVES H-CAP= -24232 .. \$MAIN FLOOR VESTIBULE 2
 MEZFLST=ZONE LIKE MVES H-CAP= -5802 .. \$MEZZANINE STAIRCASE
 MEZSTR=ZONE LIKE MFLSTR ..

\$SYSTEM SUBCOMMAND FOR UNIT HEATERS

S-CONT4=S-C MAX-SUPPLY-T=105 ..
 AC-SYS4=SYST S-TYPE=UHT
 FAN-SCHEDULE=FAN-ON4
 H-SCH=HEATON
 S-C=S-CONT4
 HEAT-SOURCE=HOT-WATER
 ZONE-NAMES=(BVES1, MVES, MFLSTR, MVES2,
 MEZFLST,MEZSTR) ..

\$SYSTEM SUBCOMMANDS FOR OTHER SYSTEMS

\$SYSTEM HAS NO COOLING COIL.SYSTEM NAME IS SZRH BUT \$WITHOUT REHEATING COIL

S-CONT1=S-C	MAX-SUPPLY-T=105 C-SCH=COOL-OFF MIN-HUMIDITY=25 B-SCH=DRS ECONO-LIMIT-T=60 ..
S-CONT2=S-C	MAX-SUPPLY-T=105 C-SCH=COOL-OFF MIN-HUMIDITY=25 BASEBOARD-SCH=DRS ECONO-LIMIT-T=60 ..
S-CONT3=S-C	MAX-SUPPLY-T=105 C-SCH=COOL-OFF MIN-HUMIDITY=25 BASEBOARD-SCH=DRS ECONO-LIMIT-T=60 ..

\$SUBCOMANDS OF SYSTEM-AIR

S-AIR1=S-A	SUPPLY-CFM=10595 RETURN-CFM=10065 OA-CONTROL=TEMP ..
S-AIR2=S-A	SUPPLY-CFM=4768 RETURN-CFM=3179 OA-CONTROL=TEMP ..
S-AIR3=S-A	SUPPLY-CFM=4238 RETURN-CFM=3814 OA-CONTROL=TEMP RECOVERY-EFF=0.6 ..

\$RUN AROUND HEAT RECOVERY SYSTEM

SYS-F1=S-FANS	F-SCH=FAN-ON1 F-C=CONSTANT-VOLUME SUPPLY-STATIC=2.25 SUPPLY-EFF=0.6 RETURN-STATIC=0.75 RETURN-EFF=0.6 NIGHT-VENT-CTRL=SCHEDULED+DEMAND NIGHT-VENT-SCH=SUMMER-VENT NIGHT-VENT-RATIOS=(1,1,1,0,0,0) NIGHT-CYCLE-CTRL=CYCLE-ON-ANY ..
SYS-F2=S-FANS	LIKE SYS-F1 F-SCH=FAN-ON2

SYS-F3=S-FANS LIKE SYS-F2
F-SCH=FAN-ON3

\$AC SYSTEM FOR THE AHU-1

AC-SYS1=SYST S-TYPE=SZRH
S-C=S-CONT1
S-A=S-AIR1
S-FANS=SYS-F1
HEAT-SOURCE=HOT-WATER
B-SCH=DRS
BASEB-S=HOT-WATER
RETURN-AIR-PATH=DUCT
HUMIDIFIER-TYPE=HOT-WATER
H-SCH=HEATON
COOLING-SCHEDULE=COOL-OFF
VENT-TEMP-SCH=VENT-SETPT
ZONE-NAMES=(MZ4,MZ5,MZ6,MEZZ1,MEZZP1,
MEZCZ,MEZCL1,MEZCL1P,MEZCL2,
MEZCL2P,MECRM) ..

AC-SYS2=SYST S-TYPE=SZRH
S-C=S-CONT2
S-A=S-AIR2
S-FANS=SYS-F2
HEAT-SOURCE=HOT-WATER
B-SCH=DRS
BASEB-S=HOT-WATER
RETURN-AIR-PATH=DUCT
H-SCH=HEATON
C-SCH=COOL-OFF
VENT-TEMP-SCH=VENT-SETPT
ZONE-NAMES=(BZ2,BZ3,BZ4,MZ1,MZ2,MZ3,PLRM) ..

AC-SYS3=SYST S-TYPE=SZRH
S-C=S-CONT3
S-A=S-AIR3
S-FANS=SYS-F3
B-SCH=DRS
HEAT-SOURCE=HOT-WATER
BASEB-S=HOT-WATER
RETURN-AIR-PATH=DUCT
HUMIDIFIER-TYPE=HOT-WATER
H-SCH=HEATON
C-SCH=COOL-OFF
VENT-TEMP-SCH=VENT-SETPT

ZONE-NAMES=(BZ1) ..

PLANT1=PLANT-ASSIGNMENT

SYSTEM-NAMES=(AC-SYS1,AC-SYS2,AC-SYS3,AC-SYS4)

DHW-GAL/MIN=1

DHW-SCH=DHW ..

DHW=SCH THRU DEC 31 (MON,FRI)(1,7)(0) (8,19)(1) (20,24)(0)
 (SAT)(1,8)(0) (9,15)(1) (16,24)(0)
 (SUN)(1,9)(0) (10,15)(1) (16,24)(0)
 (HOL)(1,24)(0) ..

\$AC-SYS1:AHU-1

\$AC-SYS2:AHU-2

\$AC-SYS3:AHU-3

\$AC-SYS4:CUH

END ..

COMPUTE SYSTEMS ..

INPUT PLANT ..

PLANT1=PLANT-ASSIGNMENT ..

PLANT-REPORT SUMMARY=(BEPS) ..

SYSBOILER=PLANT-EQUIPMENT TYPE=HW-BOILER SIZE=-999

DHWH=PLANT-EQUIPMENT	INSTALLED-NUMBER=2 ..
	TYPE=DHW-HEATER SIZE=-999

INSTALLED-NUMBER=1 ..

END ..

COMPUTE PLANT ..

STOP ..

Appendix 4

Major changes in the base case input file for HVAC system retrofit

Under LOADS program

CHANGED INFILTRATION SCHEDULE FOR SEPARATE HVAC SYSTEM

```

L/SANCT-INF-SCH1=D-SCH      (1,24) (1) ..
L/SANCT-INF-SCH2=D-SCH      (1,7) (1) (8,11) (0) (12,24)(1) ..
L/SANCT-INF-SCH3=W-SCH      (MON,SAT) L/SANCT-INF-SCH1
                             (SUN,HOL) L/SANCT-INF-SCH2 ..
L/SANCT-INF-SCH=SCH        THRU DEC 31 L/SANCT-INF-SCH3 ..

C/SANCT-INF-SCH1=D-SCH      (1,24) (1) ..
C/SANCT-INF-SCH2=D-SCH      (1,15) (1) (16,19)(0) (20,24)(1) ..
C/SANCT-INF-SCH3=D-SCH      (1,7)(1) (8,11)(0) (12,24) (1) ..
C/SANCT-INF-SCH4=D-SCH      (1,6)(1) (7,9)(0) (10,24)(1) ..
C/SANCT-INF-SCH5=D-SCH      (1,12)(1) (13,15)(0) (16,24)(1) ..
C/SANCT-INF-SCH6=D-SCH      (1,7)(1) (8,13)(0) (14,24)(1) ..
C/SANCT-INF-SCH7=W-SCH      (MON) C/SANCT-INF-SCH1
                             (TUE)C/SANCT-INF-SCH2
                             (WED) C/SANCT-INF-SCH3
                             (THU) C/SANCT-INF-SCH4
                             (FRI) C/SANCT-INF-SCH4
                             (SAT) C/SANCT-INF-SCH5
                             (SUN) C/SANCT-INF-SCH6
                             (HOL) C/SANCT-INF-SCH1 ..
C/SANCT-INF-SCH=SCH        THRU DEC 31 C/SANCT-INF-SCH7 ..

```

Under SYSTEMS program

\$-----HVAC SYSTEMS SCHEDULES

```

FAN-ON1=SCHEDULE          THRU DEC 31  (ALL)(1,4)(0) (5,19)(1) (20,24)(0) ..
FAN-ON2=SCHEDULE          THRU DEC 31  (ALL)(1,4)(0) (5,19)(1) (20,24)(0) ..
FAN-ON3=SCHEDULE          THRU DEC 31  (MON,FRI)(1,7)(0) (8,21)(1)
(22,24)(0)
                             (WEH)(1,24)(0) ..

```

\$-----FOR AHU-5; C/SANCTUARY SCHEDULE

C-S-FAN-ON1=D-SCH (1,24) (0) ..
 C-S-FAN-ON2=D-SCH (1,15) (0) (16,19)(1) (20,24)(0) ..
 C-S-FAN-ON3=D-SCH (1,7)(0) (8,11)(1) (12,24) (0) ..
 C-S-FAN-ON4=D-SCH (1,6)(0) (7,9)(1) (10,24)(0) ..
 C-S-FAN-ON5=D-SCH (1,12)(0) (13,15)(1) (16,24)(0) ..
 C-S-FAN-ON6=D-SCH (1,7)(0) (8,13)(1) (14,24)(0) ..
 C-S-FAN-ON7=W-SCH (MON) C-S-FAN-ON1 (TUE) C-S-FAN-ON2
 (WED) C-S-FAN-ON3 (THU) C-S-FAN-ON4
 (FRI) C-S-FAN-ON4 (SAT) C-S-FAN-ON5
 (SUN) C-S-FAN-ON6 (HOL) C-S-FAN-ON1 ..
 C/SANCT-FAN-ON=SCH THRU DEC 31 C-S-FAN-ON7 ..

\$---HEATSETPT FOR DIFF. SYSTEMS

HEATSETPT1=SCH THRU DEC 31 (ALL)(1,5)(61) (6,19)(70) (20,24)(61) ..
 HEATSETPT2=SCH THRU DEC 31 (ALL)(1,5)(61) (6,19)(68) (20,24)(61) ..
 HEATSETPT3=SCH THRU DEC 31 (MON,FRI)(1,7)(61) (8,22)(68) (23,24)(60)
 (WEH)(1,24)(61) ..

C-S-HEATSETPT1=D-SCH (1,24) (61) ..
 C-S-HEATSETPT2=D-SCH (1,15) (61) (16,19)(70) (20,24)(61) ..
 C-S-HEATSETPT3=D-SCH (1,7)(61) (8,11)(70) (12,24) (61) ..
 C-S-HEATSETPT4=D-SCH (1,6)(61) (7,9)(70) (10,24)(61) ..
 C-S-HEATSETPT5=D-SCH (1,12)(61) (13,15)(70) (16,24)(61) ..
 C-S-HEATSETPT6=D-SCH (1,7)(61) (8,13)(70) (14,24)(61) ..
 C-S-HEATSETPT7=W-SCH (MON) C-S-HEATSETPT1
 (TUE) C-S-HEATSETPT2
 (WED) C-S-HEATSETPT3
 (THU) C-S-HEATSETPT4
 (FRI) C-S-HEATSETPT4
 (SAT) C-S-HEATSETPT5
 (SUN) C-S-HEATSETPT6
 (HOL) C-S-HEATSETPT1 ..
 C/SANCT-HEATSETPT=SCH THRU DEC 31 C-S-HEATSETPT7 ..

\$--DAY-RESER-SCH FOR ALL SYSTEMS

DRS1=DAY-RESET-SCH SUPPLY-HI=1 SUPPLY-LO=0 OUTSIDE-HI=68
 OUTSIDE-LO=0 ..
 DRS= RESET-SCH THRU DEC 31 (ALL) DRS1 ..

\$--COOLING AND HEATING SCHEDULE FOR ALL SYSTEMS

COOL-OFF=SCHEDULE THRU DEC 31 (ALL)(1,24)(0) ..

HEATON=SCH THRU MAY 15 (ALL)(1,24)(1)
 THRU AUG 31 (ALL)(1,24)(0)
 THRU DEC 31 (ALL)(1,24)(1) ..

SUMMER-VENT=SCH THRU MAY 31 (ALL)(1,24)(0)
 THRU OCT 31 (ALL)(1,24)(1)
 THRU DEC 31 (ALL)(1,24)(0) ..
 VENT-SETPT=SCH THRU DEC 31 (ALL)(1,24)(74) ..

\$ZONE SUB-COMMANDS

ZCON1=Z-C D-H-T=68 H-T-SCH=HEATSETPT1
 B-C=THERMOSTATIC T-TYPE=PROPORTIONAL
 T-R=4 ..

ZCON2=Z-C D-H-T=68 H-T-SCH=HEATSETPT2
 B-C=THERMOSTATIC T-TYPE=PROPORTIONAL
 T-R=4 ..

ZCON3=Z-C D-H-T=68 H-T-SCH=HEATSETPT3
 B-C=THERMOSTATIC T-TYPE=PROPORTIONAL
 T-R=4 .. \$GYM/HALL

ZCON5=Z-C D-H-T=70 H-T-SCH=C/SANCT-
 HEATSETPT B-C=THERMOSTATIC T-TYPE=PROPORTIONAL
 T-R=4 ..

ZAIR1=Z-A OA-CFM/PER=10 AIR-CHANGES/HR=4 ..
 ZAIR2=Z-A OA-CFM/PER=15 AIR-CHANGES/HR=4 ..
 ZAIR3=Z-A OA-CFM/PER=10
 AIR-CHANGES/HR=4 ..
 ZAIR4=Z-A OA-CFM/PER=10 AIR-CHANGES/HR=4 ..

\$--SYSTEM DESCRIPTION

\$--GYM/HALL; AHU-3

BZ1=ZONE Z-TYPE=CONDITIONED Z-C=ZCON3
 Z-A=ZAIR3 B-R= -5120 .. \$BTU/HR

\$--SERVICE ZONES; AHU-2

BZ2=ZONE Z-TYPE=CONDITIONED Z-C=ZCON2
 Z-A=ZAIR2
 ASSIGNED-CFM=106
 B-R= -512 ..
 BZ3=ZONE LIKE BZ2 ASSIGNED-CFM=1430

EXHAUST-CFM=450 B-R=-2816 ..

BZ4=ZONE LIKE BZ3 ASSIGNED-CFM=318 EXHAUST-CFM=225

B-R= -0 ..

MZ1=ZONE LIKE BZ4 ASSIGNED-CFM=954 EXHAUST-CFM=225

B-R= -1280 ..

MZ2=ZONE LIKE MZ1 ASSIGNED-CFM=1059 EXHAUST-CFM=450

B-R=-24403 ..

MZ3=ZONE LIKE MZ2 ASSIGNED-CFM=424 EXHAUST-CFM=150

B-R= -1024 ..

PLRM=ZONE LIKE MZ3 ASSIGNED-CFM=424 EXHAUST-CFM=100

B-R= -1024 ..

\$---C/L SANCTUARY; AHU-5

MZ4=ZONE

Z-T=CONDITIONED

Z-C=ZCON5

Z-A=ZAIR4

ASSIGNED-CFM=3952

EXHAUST-CFM=64

B-R= -7781 ..

\$C/SANCTUARY

MZ5=ZONE

LIKE MZ4 ASSIGNED-CFM=2702

Z-C=ZCON5 B-R=-81912 ..

\$L/SANCTUARY

\$---LOBBY, CLASS ROOMS AND OTHER AREA; AHU-1

MZ6=ZONE

Z-TYPE=CONDITIONED Z-C=ZCON1

Z-A=ZAIR1 ASSIGNED-CFM=2236

B-R=-41843 ..

\$LOBBY

MEZZ1=ZONE

LIKE MZ6 ASSIGNED-CFM=170

B-R=-512 ..

\$MENZZANINE OFFICE

MEZZP1=ZONE

Z-TYPE=PLENUM ..

\$MEZZANINE OFFICE PLENUM

MEZCZ=ZONE

LIKE MEZZ1 ASSIGNED-CFM=848

B-R=-179 ..

\$SPACE ABOVE THE LOBBY

MEZCL1=ZONE

LIKE MEZZ1 ASSIGNED-CFM=477

B-R=-2389 ..

\$CLASSROOM ABOVE C/SANCT

MEZCL1P=ZONE

LIKE MEZZP1 ..

\$CLASSROOM1 PLENUM

MEZCL2=ZONE

LIKE MEZCL1

ASSIGNED-CFM=477 ..

\$CLASSROOM ABOVE L/SANCT

MEZCL2P=ZONE LIKE MEZCL1P ..

MECRM=ZONE Z-TYPE=UNCONDITIONED .. \$CLASSROOM2 PLENUM

\$MECHANICAL ROOM

\$----UNIT HEATER SYSTEMS DESCRIPTION

FAN-ON4=SCH THRU DEC 31 (MON,FRI)(1,7)(0) (8,19)(.8) (20,24)(0)
(SAT)(1,13)(0) (14,18)(.5) (19,24)(0)
(SUN)(1,8)(0) (9,15)(.5) (16,24)(0)
(HOL) (1,24)(0) ..

HEATSETPT4=SCH THRU DEC 31 (MON,FRI)(1,7)(55)(8,19)(72)(20,24)(0)
(SAT)(1,7)(55)(8,19)(70)(20,24)(55)
(SUN)(1,8)(55)(9,19)(70)(20,24)(55)
(HOL)(1,24)(55) ..

BVES1=ZONE
Z-TYPE=CONDITIONED
D-H-T=72
H-T-SCH=HEATSETPT4
H-CAP=5802 ..

\$BASEMENT

```

VESTIBULE
MVES=ZONE      LIKE BVES1 H-CAP= -18430 .. $MAIN FLOOR VESTIBULE 1
MFLSTR=ZONE    LIKE MVES  H-CAP= -5802  .. $MAIN FLOOR STAIRCASE
MVES2=ZONE     LIKE MVES  H-CAP= -24232 .. $MAIN FLOOR VESTIBULE 2
MEZFLST=ZONE   LIKE MVES  H-CAP= -5802  .. $MEZZANINE STAIRCASE
MEZSTR=ZONE    LIKE MFLSTR ..

```

SYSTEM SUBCOMMAND FOR UNIT HEATERS

S-CONT4=S-C MAX-SUPPLY-T=105 ..
AC-SYS4=SYST S-TYPE=UHT F-SCH=FAN-ON4 H-SCH=HEATON
S-C=S-CONT4 HEAT-S=HOT-WATER
ZONE-NAMES=(BVES1, MVES, MFLSTR, MVES2,
MEZFLST,MEZSTR) ..

S-CONT1=S-C MAX-SUPPLY-T=105 C-SCH=COOL-OFF
MIN-HUMIDITY=25 B-SCH=DRS

S-CONT2=S-C	ECONO-LIMIT-T=60 .. MAX-SUPPLY-T=105 MIN-HUMIDITY=25	C-SCHEDULE=COOL-OFF B-SCH=DRS
-------------	--	----------------------------------

S-CONT3=S-C **ECONO-LIMIT-T=60 ..** **C-SCH=COOL-OFF**
MAX-SUPPLY-T=105 **B-SCH=DRS**
MIN-HUMIDITY=25
ECONO-LIMIT-T=60 ..

SSUBCOMANDS OF SYSTEM-AIR

S-AIR1=S-A **OA-CONTROL=TEMP ..**

S-AIR2=S-A **SUPPLY-CFM=4768**
RETURN-CFM=3179
OA-CONTROL=TEMP ..

S-AIR3=S-A **SUPPLY-CFM=4238**
RETURN-CFM=3814
OA-CONTROL=TEMP
RECOVERY-EFF=0.6 ..
\$RUN AROUND HEAT RECOVERY SYSTEM

SYS-F1=S-FANS **F-SCH=FAN-ON1**
FAN-CONTROL=CONSTANT-VOLUME
SUPPLY-STATIC=2.25
SUPPLY-EFF=0.6
RETURN-STATIC=0.75
RETURN-EFF=0.6
NIGHT-VENT-CTRL=SCHEDULED+DEMAND
NIGHT-VENT-SCH=SUMMER-VENT
NIGHT-VENT-RATIOS=(1,1,1,0,0,0)
NIGHT-CYCLE-CTRL=CYCLE-ON-ANY ..

SYS-F2=S-FANS **LIKE SYS-F1**
F-SCH=FAN-ON2 ..

SYS-F3=S-FANS **LIKE SYS-F1**
F-SCH=FAN-ON3
NIGHT-CYCLE-CTRL=STAY-OFF ..

SYS-F5=S-FANS **LIKE SYS-F3**
F-SCH=C/SANCT-FAN-ON ..

\$AC SYSTEM FOR THE AHU-1

AC-SYS1=SYST **S-TYPE=SZRH** **S-C=S-CONT1** **S-A=S-AIR1**
S-FANS=SYS-F1 **HEAT-S=HOT-WATER**
B-SCH=DRS **BASEB-S=HOT-WATER**
RETURN-AIR-PATH=DUCT
HUMIDIFIER-TYPE=HOT-WATER
H-SCH=HEATON **C-SCH=COOL-OFF**
\$NO MECHANICAL COOLING
VENT-TEMP-SCH=VENT-SETPT
ZONE-NAMES=(MZ6,MEZZ1,MEZZP1,
MEZCZ,MEZCL1,MEZCL1P,MEZCL2,
MEZCL2P,MECRM) ..

AC-SYS2=SYST **S-TYPE=SZRH** **S-C=S-CONT2** **S-A=S-AIR2**

S-FANS=SYS-F2 HEAT-S=HOT-WATER B-SCH=DRS
 BASEB-S=HOT-WATER RETURN-AIR-PATH=DUCT
 H-SCH=HEATON C-SCH=COOL-OFF
 \$NO MECHANICAL COOLING
 VENT-TEMP-SCH=VENT-SETPT
 ZONE-NAMES=(BZ2,BZ3,BZ4,MZ1,MZ2,MZ3,PLRM) ..

AC-SYS3=SYST S-TYPE=SZRH S-C=S-CONT3 S-A=S-AIR3
 S-FANS=SYS-F3 B-SCH=DRS HEAT-S=HOT-WATER
 BASEB-S=HOT-WATER RETURN-AIR-PATH=DUCT
 HUMIDIFIER-TYPE=HOT-WATER H-SCH=HEATON

 C-SCH=COOL-OFF VENT-TEMP-SCH=VENT-SETPT
 ZONE-NAMES=(BZ1) ..

AC-SYS5=SYSTEM S-TYPE=SZRH S-C=S-CONT1 S-A=S-AIR1
 S-FANS=SYS-F5 HEAT-S=HOT-WATER
 B-SCH=DRS BASEB-S=HOT-WATER
 RETURN-AIR-PATH=DUCT H-SCH=HEATON
 C-SCH=COOL-OFF
 ZONE-NAME=(MZ4, MZ5) ..

PLANT1=PLANT-ASSIGNMENT SYSTEM-NAMES=(AC-SYS1,AC-SYS2,
 AC-SYS3, AC-SYS4,AC-SYS5)
 DHW-GAL/MIN=1
 DHW-SCH=DHW ..

DHW=SCHEDULE THRU DEC 31 (MON,FRI)(1,7)(0) (8,19)(1) (20,24)(0)
 (SAT)(1,8)(0) (9,15)(1) (16,24)(0)
 (SUN)(1,9)(0) (10,15)(1) (16,24)(0)
 (HOL)(1,24)(0) ..

\$AC-SYS1:AHU-1
 \$AC-SYS2:AHU-2
 \$AC-SYS3:AHU-3
 \$AC-SYS4:CUH
 \$AC-SYS5:AHU4 (FOR SANCTUARIES)
 END ..
 COMPUTE SYSTEMS ..
 INPUT PLANT ..
 PLANT1=PLANT-ASSIGNMENT ..
 PLANT-REPORT
 SYSBOILER=PLANT-EQUIPMENT

SUMMARY=(BEPS) ..
 TYPE=HW-BOILER SIZE=999

INSTALLED-NUMBER=2 ..

DHWH=PLANT-EQUIPMENT

TYPE=DHW-HEATER SIZE=999

INSTALLED-NUMBER=1 ..

END ..
COMPUTE PLANT ..
STOP ..